

**BUILDING MATERIALS EVALUATION COMMISSION  
(BMEC)  
AUTHORIZATION REPORT**

---

**DUCTLESS WASHROOM EXHAUST**

Date of Authorization: December 14, 1978

AMENDED: July 12, 1979

Revised: July 26, 2012 (contact information revised)

BMEC REFERENCE: BMEC-78-04-012

**IN THE MATTER OF** Section 18 (4) (b) of the Building Code Act, 1974

**AND IN THE MATTER OF** an application by:

Rush-Hampton Industries  
4275 Church Street, Suite 1001  
Sanford, Florida, 32771  
Tel: 407 324-5887  
Fax: 407 325-3991  
Web: [www.tekquestindustries.com](http://www.tekquestindustries.com)

**AGENT:**

Wally Iwamoto  
Downstream Components  
64 Mithollow Sq.  
Scarborough, Ontario  
M1E 4P4

**ON THE SUBJECT OF:**

CA/90 Ductless Fan to be used as alternate to a window or mechanical ventilation in toilets and bathrooms of new construction.

**THE COMMISSION HEREBY AUTHORIZES** the use of the aforementioned matter subject to the following terms and conditions:

1. Where in the opinion of the COMMISSION negative experience indicates that this authorization should be amended and/or terminated, the COMMISSION may by written notice to the applicant or the agent at the above address, withdraw the authorization and no further installations shall be made subsequent to the effective date of the termination as set out in the written notice.
2. The COMMISSION does not assume or undertake to discharge any responsibility of the applicant to any other party or parties and does not in any manner warrant or guarantee the correctness and/or the successful performance of the subject matter.
3. This AUTHORIZATION may be mentioned in promotional and/or advertising material, however, it is not to be used expressly or impliedly as an endorsement of any product, material, technique or design which is described herein.
4. This AUTHORIZATION is not transferable to any other party. If the APPLICANT makes any revision or change to the address or the materials, technique, design, system and/or use of the same shall automatically be cause for termination, unless prior approval is granted for such revision or change by the COMMISSION.
5. Construction and installation shall be in conformance to all applicable governing legislation except that compliance with the terms and conditions described herein shall be deemed not to be a contravention of the Building Code. Where applicable, any change in the Act, Regulation or Code provisions shall be grounds for re-evaluation by the COMMISSION.

**AND SPECIFIC REQUIREMENTS:**

6. Until further written notice from the Commission the Applicant and/or his agent shall notify the Commission in writing within thirty days of completion of the installation of each system pursuant to this authorization with all the necessary information respecting the owner and location of the installation, also what type of follow up procedure is to be used in regard to replacing the filter, and what quantity of filter stock on hand is available locally.
7. The permitted use of this fan in paragraph 5 in two piece washrooms is only if neither of the two pieces are bathtub or shower.

BUILDING MATERIALS EVALUATION COMMISSION