

Ruling of the Minister
Ministry of Municipal Affairs and Housing
777 Bay Street, 2nd Floor
Toronto, Ontario M5G 2E5

Tel: 416 585-4234
Fax: 416 585-7531
Web: www.obc.mah.gov.on.ca



RULING OF THE MINISTER OF MUNICIPAL AFFAIRS AND HOUSING

Pursuant to Section 29(1)(a) of the *Building Code Act, 1992*, the Director of the Building and Development Branch, as delegate of the Minister of Municipal Affairs and Housing (the "Minister"), hereby approves the use of **InsulROCK and PUC Exterior Insulation Finish Systems** subject to the following terms and conditions;

Minister Ruling No. 00-13-84 (12969-R)
Minister Ruling File No. 06-11
Issued on November 1, 2006

1. MANUFACTURER

DuROCK Alfacing International Limited
101-B Roytec Road
Woodbridge, Ontario, L4L 8A9

Tel: 905 856-0133
888 238-6345
Fax: 905 856-9654

2. MANUFACTURING FACILITIES

101-B Roytec Road
Woodbridge, Ontario, L4L 8A9

3. SPECIFIC CONDITIONS

- (a) The use of **InsulROCK and PUC Exterior Insulation Finish Systems** is approved in respect to the requirements for cladding contained in Section 9.27. and Clause 3.2.3.7.(7)(b) of Ontario Regulation 403/97, as amended or remade from time to time (the "Ontario Building Code");
- (b) The use of **InsulROCK and PUC Exterior Insulation Finish Systems** must comply with the Building Code Act, 1992; and, except as specifically provided otherwise in this Ruling, with the Ontario Building Code;
- (c) The use of **InsulROCK and PUC Exterior Insulation Finish Systems** must be in accordance with Canadian Construction Materials Centre (CCMC) Evaluation Report N^o CCMC 12969-R (the "Evaluation Report") issued on May 24, 2000, re-evaluated on December 8, 2005, and revised on January 19, 2006; provided that the references in that report to the National Building Code of Canada, 1995, including those listed in column 1 below, shall be deemed references to the Ontario Building Code listed in column 2 below, as described in the following table;

National Building Code References	Ontario Building Code References
3. 3.1.4.2. 3.1.5.11.(2)(e) 3.1.5.11.(3) 3.2.3.7.(7)(b) 9. 9.10.16.10. 9.23.3.5. 9.25.1.2. 9.27. A-9.25.1.2. NBC	3 3.1.4.2. 3.1.5.11.(2)(e) 3.1.5.11.(3) 3.2.3.7.(7)(b) 9. 9.10.16.10. 9.23.3.5. 9.25.1.2. 9.27. A-9.25.1.2. OBC
column 1	column 2

- (d) **InsulROCK and Pucc Exterior Insulation Finish Systems** shall not be used on exposing building faces regulated by Sentences 3.2.3.7.(1) and 3.2.3.7.(4), or where the unprotected opening permitted in table 9.10.14.11, of the Ontario Building Code, is between 0 -10%;
- (e) A copy of this Ruling shall be attached to the application for a building permit; and
- (f) This Ruling is valid only for **InsulROCK and Pucc Exterior Insulation Finish Systems** manufactured at the facilities outlined in Section 2. (Manufacturing Facilities) of this Ruling.

4. GENERAL CONDITIONS

The Minister or his/her delegate may amend or revoke this Ruling if:

- (a) the Evaluation Report is amended by the CCMC;
- (b) the Evaluation Report expires in accordance with the CCMC's General Conditions for Evaluation Reports;
- (c) the Evaluation Report is rendered void in accordance with the CCMC's General Conditions for Evaluation Reports by reason of alterations to the product or relocation of manufacturing facilities, described in the Evaluation Report, without prior agreement by the CCMC;
- (d) the Evaluation Report is withdrawn by the CCMC in accordance with the CCMC's General Conditions for Evaluation Reports where, in the opinion of the CCMC:
 - (i) the level of performance, in-situ, of the product described in the Evaluation Report is unsatisfactory;

- (ii) the proponent of such product fails to fulfil its obligations as set out in the CCMC's General Conditions for Evaluation Reports; or
 - (iii) such product may pose any danger to the health or safety of the user of such product;
- (e) the Minister or his/her delegate determines that the use of the material, system or building design authorized by this Ruling:
 - (i) will not comply with the Building Code Act, 1992 or any relevant law as they may be amended or re-enacted from time to time; or
 - (ii) provides an unsatisfactory level of performance, in situ; or
- (f) any Ontario Building Code provision relevant to this Ruling is amended or remade.

DATED AT TORONTO THIS 1 DAY OF NOVEMBER 2006.

DAVID BREZER, DIRECTOR