

INDEX

POTENTIAL CHANGES TO ONTARIO'S BUILDING CODE:

FALL 2016 CONSULTATION

Ontario.ca/buildingcode

Important Information about this Index

The following are brief explanations for some of the columns and terms included in the “Index - Potential Changes to Ontario’s Building Code”:

- “Code Reference” means the provision of the current Building Code (Ontario Regulation 332/12 as amended) that may be affected by the proposal, if adopted.
- A “Topic” has been identified for certain Building Code proposals in cases where those proposals support areas referred to in the Overview Summary Document. When a “Topic” cell is empty those proposals are not specially referenced in the Overview Summary Document.
- In “Source”, mNBC or mNPC, is a reference to the model national codes which include the model National Building Code of Canada and the model National Plumbing Code of Canada. These proposals, if adopted, would serve to increase harmonization between Ontario’s Building Code and the model national codes.

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-A-01-01-01</u>	Div. A / 1.1.2.2.	Amend application of Parts 3, 4, 5, and 6 by introducing specific requirements for Group C retirement homes.	Retirement Homes	Ontario
<u>A-01-01-01</u>	Div. A / 1.1.2.2.(6)	Include a new Clause 1.1.2.2.(6) in Division A that clarifies that Section 3.18 is applicable to Demountable Event Structures (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario
<u>A-01-01-02</u>	Div. A / 1.1.2.2. Div. A / 1.1.2.4. Div. A / 1.1.2.8.	To address buildings constructed below grade that would not be considered to have a <i>building area</i> as defined in Division A, 1.4.1.2. for the purpose of determining the applicability of Division B.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-A-01-01-02</u>	Div. A / 1.1.2.4.	Revise the application of Part 9 by excluding retirement homes from its application.	Retirement Homes	Ontario
<u>A-01-01-03</u>	Div. A / 1.1.2.7.	Add new requirements for installing existing factory-constructed buildings that are built outside of Ontario to meet the Ontario's Building Code standards.		Ontario
<u>R-A-01-01-03</u>	Div. A / 1.1.3.2.	Revise the provision that permits an alternate method of determining building height so that it is applicable to Group C occupancies other than retirement homes.	Retirement Homes	Ontario
<u>A-01-03-01</u>	Div. A / 1.3.1.1.(1)(i)	Include a new Clause 1.3.1.1.(1)(i) in Division A that clarifies that Demountable Event Structures (Temporary Stages) are considered designated structures in the Building Code.	Demountable Event Structures (Temporary Stages)	Ontario
<u>A-01-04-01</u>	Div. A / 1.4.1.2.(1)	Add defined terms for <i>Apparent Sound Transmission Class (ASTC)</i> and <i>Sound Transmission Class</i> .	Sound Transmission	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>A-01-04-02</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>carbon monoxide alarm</i> .	Carbon Monoxide	Ontario
<u>R-A-01-04-01</u>	Div. A / 1.4.1.2.(1)	Extend definition of <i>residential occupancy</i> classification to include retirement homes.	Retirement Homes	Ontario
<u>R-A-01-04-02</u>	Div. A / 1.4.1.2.(1)	Amend the defined term <i>care occupancy</i> to specifically exclude retirement homes.	Retirement Homes	Ontario
<u>A-01-04-03</u>	Div. A / 1.4.1.2.(1)	This proposed change amends the definition of <i>closure</i> by adding the term “damper” and revises the appendix note for the term “fire separation”.		mNBC
<u>A-01-04-04</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>common trap</i> .		Ontario
<u>A-01-04-05</u>	Div. A / 1.4.1.2.(1)	Define <i>dangerous goods</i> as products regulated by either the Transportation of Dangerous Goods Regulation or the Workplace Hazardous Material Information System.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>A-01-04-06</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>demountable event structures</i> (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario
<u>A-01-04-07</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>emergency floor drain</i> .		Ontario
<u>A-01-04-08</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>flat insulating concrete form</i> .		Ontario
<u>A-01-04-09</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>flight</i> .	Stairs, Guards & Handrails	mNBC
<u>A-01-04-10</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>gang trap</i> .		Ontario
<u>A-01-04-11</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>grade</i> .		Ontario
<u>A-01-04-12</u>	Div. A / 1.4.1.2.(1)	Amend definition of <i>heritage building</i> .		Ontario
<u>A-01-04-13</u>	Div. A / 1.4.1.2.(1)	Add definition of <i>house</i> .	Secondary Suites	Ontario
<u>A-01-04-14</u>	Div. A / 1.4.1.2.(1)	Add a new definition for <i>leaching chamber</i> and amend the definition of <i>Type A dispersal bed</i> to reflect the use of <i>leaching chambers</i> .		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>A-01-04-15</u>	Div. A / 1.4.1.2.(1)	Amend definition of post-disaster buildings Bio Gas plants and wind turbines are not to be designed as post-disaster buildings per mNBC Add an appendix note for post-disaster buildings per mNBC.		Ontario
<u>A-01-04-16</u>	Div. A / 1.4.1.2.(1)	Add definition for <i>public use</i> to clarify the distinction between washrooms for versus a private washroom for use by a single occupant.		Ontario
<u>A-01-04-17</u>	Div. A / 1.4.1.2.(1)	Add new definition for <i>receiving fixture</i> . Currently there are no restrictions on what fixtures can be used to receive waste from indirectly connected waste pipes.		Ontario
<u>R-A-01-04-03</u>	Div. A / 1.4.1.2.(1)	Define <i>retirement home</i> to include all licensed retirement homes.	Retirement Homes	Ontario
<u>A-01-04-18</u>	Div. A / 1.4.1.2.(1)	Add definition of <i>run</i> .	Stairs, Guards & Handrails	mNBC
<u>A-01-04-19</u>	Div. A / 1.4.1.2.(1)	Add new definition for <i>running trap</i> .		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>A-01-04-20</u>	Div. A / 1.4.1.2.(1)	Add definitions for <i>solid masonry</i> and <i>solid masonry units</i> .		mNBC
<u>A-01-04-21</u>	Div. A / 1.4.1.2.(1)	Add a definition for <i>tapered tread</i> .	Stairs, Guards & Handrails	mNBC
<u>B-03-01-01</u>	Div. B / 3.1.1.2.(1)	Add clause to require radon mitigation in geographic areas where radon is above 200 Bq/m3.	Radon Mitigation	Ontario
<u>CC-B-03-01-01</u>	Div. B / 3.1.1.4.	The proposed change would require electric vehicle charging equipment in all Part 3 <i>buildings</i> where parking is provided in the building except for multi-unit apartment buildings .	Climate Change	Ontario
<u>B-03-01-02</u>	Div. B / Table 3.1.3.1.	Add a note to explain that FRR and Fire Separation are not required.	Fire Safety	Ontario
<u>R-B-03-01-01</u>	Div. B / 3.1.3.2.	Revise the provisions for prohibition of occupancy combinations to recognize specific requirements for retirement homes.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-01-03</u>	Div. B / 3.1.4.1.	Introduce a new appendix note reminding code users that the provisions for spatial separation and exposure protection are independent of the type of building construction.	Fire Safety	mNBC
<u>B-03-01-04</u>	Div. B / 3.1.4.2.	Introduce a new Sentence (2) for the protection of walk-in cooler or freezer consisting of factory-assembled panels containing foamed plastic insulation; and, a new Sentence (3) as a pointer to Article 3.1.13.2. for the flame-spread rating requirement for doors.	Fire Safety	mNBC
<u>B-03-01-05</u>	Div. B / 3.1.4.7.(6)	Add strandboard and waferboard construction materials as an acceptable substrate for heavy timber roof construction.	Fire Safety	mNBC
<u>B-03-01-06</u>	Div. B / 3.1.5.2.	Add self-adhesive tapes as a minor component permitted in a building required to be of non-combustible construction.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-01-07</u>	Div. B / 3.1.5.5.	Revise Article 3.1.5.5. to provide greater clarity regarding the requirements for combustible components that are permitted for exterior walls of buildings required to be of noncombustible construction.	Fire Safety	Ontario
<u>B-03-01-08</u>	Div. B / 3.1.5.6.(1) Div. B / 3.1.5.6.(2) Div. B / 3.1.5.6.(3)	Relocate the requirements for factory-assembled wall panels containing foamed plastic insulation from Sentences 3.1.5.12.(6) and (7) for interior and exterior wall application in one Article.	Fire Safety	mNBC
<u>B-03-01-09</u>	Div. B / 3.1.5.10.	Relocate the requirement for combustible millwork (Sentence 3.1.5.7.(1)) as a new Sentence (4) and clarifies interior wall finishes permitted in a non-combustible construction.	Fire Safety	mNBC
<u>B-03-01-10</u>	Div. B / 3.1.5.12.	Clarify the requirements for the protection of combustible insulation, excluding foamed plastics, from adjacent spaces within a building.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-01-11</u>	Div. B / 3.1.5.12.(4)	Reference three new ASTM standards (i.e. ASTM-C1177/C1177M, "Specification for Glass Mat Gypsum Substrate for Use as Sheathing," ASTM C1178/C1178M, "Specification for Glass Mat Water Resistant Backing Panel" and ASTM C1658/C1658M, "Specification for Glass Mat Gypsum Panels") as acceptable referenced documents for thermal barriers consisting of Type-X gypsum board.	Fire Safety	mNBC
<u>R-B-03-01-02</u>	Div. B / 3.1.5.13.	Revise Article 3.1.5.13. to extend current prohibitions against the use of combustible framing in interior walls to retirement homes.	Retirement Homes	Ontario
<u>B-03-01-12</u>	Div. B / 3.1.5.13.	Introduce a new Article combining all requirements for the protection of foamed plastic insulation from a fire within a building.	Fire Safety	mNBC
<u>R-B-03-01-03</u>	Div. B / 3.1.5.14.	Provides restrictions with respect to permitted combustible construction in a retirement home.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-01-13</u>	Div. B / 3.1.5.16.(4)	Add a new Sentence to prohibit the use of combustibile insulation as a means of converting a non-listed piping material to meet listing requirements that is unable to achieve the listings on its own without the insulation (e.g. in plenums and high buildings).	Fire Safety	Ontario
<u>B-03-01-14</u>	Div. B / 3.1.7.1.	Clarify that the fire-resistance rating of factory-built and field-applied grease duct enclosures need to comply with the new referenced standard CAN/ULC-S144, "Standard Method of Fire Resistance Test - Grease Duct Assemblies."	Fire Safety	mNBC
<u>B-03-01-15</u>	Div. B / 3.1.8.5.	Provide installation requirements for smoke dampers used as closures in required fire separations and location of leakage-rated doors in a building.	Fire Safety	mNBC
<u>B-03-01-16</u>	Div. B / 3.1.8.4.	Provide the leakage rates of smoke dampers and combination fire/smoke dampers and the leakage rates of doors.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-01-17</u>	Div. B / 3.1.8.7.	Require that an air-transfer opening or a duct that penetrates an assembly required to be a fire separation be equipped with either a fire or a smoke damper, or a combination fire/smoke damper.	Fire Safety	mNBC
<u>B-03-01-18</u>	Div. B / 3.1.8.8.	Waive the requirements for fire dampers when specific criteria are met.	Fire Safety	mNBC
<u>B-03-01-19</u>	Div. B / 3.1.8.	Waive the requirements for smoke dampers when specific criteria are met.	Fire Safety	mNBC
<u>B-03-01-20</u>	Div. B / 3.1.8.9.(3)	Introduce an appendix note to Sentence 3.1.8.9.(3) confirming the intent of the provision that fire damper installation requirement applies also to combination fire/smoke damper.	Fire Safety	mNBC
<u>B-03-01-21</u>	Div. B / 3.1.8.	Introduce requirements for the installation of smoke dampers.	Fire Safety	mNBC
<u>B-03-01-22</u>	Div. B / 3.1.8.12.	Reformat the requirements for hold-open devices.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-01-23</u>	Div. B / 3.1.9.	Permit electrical outlet boxes to penetrate a fire separation or a membrane forming part of an assembly required to have a fire-resistance rating without the need for a fire stop under certain conditions.	Fire Safety	mNBC
<u>B-03-01-24</u>	Div. B / 3.1.11.7.	Introduce other wood products that perform as well as the fire block materials currently listed.	Fire Safety	mNBC
<u>R-B-03-01-04</u>	Div. B / 3.1.13.7.	Revise Article 3.1.17.1. to extend the current requirements for flame-spread ratings of interior finishes for retirement homes in high buildings.	Retirement Homes	Ontario
<u>B-03-01-25</u>	Div. B / 3.1.15.2.(2)	Add a new exception for steel roof panels in a steel building system to be dispensed from the classification requirement for roof covering.	Fire Safety	mNBC
<u>R-B-03-01-05</u>	Div. B / 3.1.17.1.	Revise table 3.1.17.1. to require that the appropriate floor area is used to determine the occupant load in a retirement home.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-01-26</u>	Div. B / 3.1.19.1. Div. B / 9.1.1.5.	Revise Sentence 3.1.19.1.(1) and include an appendix note to clarify that certain exceptions as permitted under the Electrical Safety Code may apply. Harmonize requirements related to clearances between buildings and electrical conductors with requirements of the Electrical Safety Code Review application of requirement to not permit construction of a building under a 120v overhead cable.	Fire Safety	Ontario
<u>B-03-02-01</u>	Div. B / 3.2.1.2.(1)	Clarify the sprinkler requirements for a storage garage in single- and multi-family residential buildings.	Fire Safety	mNBC
<u>R-B-03-02-01</u>	Div. B / 3.2.2.41A. Div. B / 3.2.2.41B. Div. B / 3.2.2.41C. Div. B / 3.2.2.41D. Div. B / 3.2.2.41E.	Provide construction requirements for retirement homes that are the same as those applicable to similar buildings designed under the mNBC.	Retirement Homes	Ontario
<u>B-03-02-02</u>	Div. B / 3.2.3.6.	Clarify permitted roof soffit projections when facing a street, lane or a public thoroughfare.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-02-03</u>	Div. B / 3.2.3.19.	Add a new Sentence to alert building occupants that the fire alarm system has been activated in a connected building.	Fire Safety	Ontario
<u>B-03-02-04</u>	Div. B / 3.2.4.1.(2)	Clarify that the occupant load limit of 75 applies to low- and medium-hazard industrial occupancies.	Fire Safety	mNBC
<u>B-03-02-05</u>	Div. B / 3.2.4.6. Div. B / 3.2.10.1 Div. A / 3.2.10.1.(1)	Add a reference to the Building Code for the new CAN/ULC- S1001, "Integrated Systems Testing of Fire Protection and Life Safety Systems and relocates the requirements to a new Subsection 3.2.10.Integrated Fire Protection and Life Safety Systems".	Fire Safety	mNBC
<u>B-03-02-06</u>	Div. B / 3.2.4.8.	Clarify the application of the CAN/ULC-S561, "Installation and Services for Fire Signal Receiving Centres and Systems".	Fire Safety	mNBC
<u>B-03-02-07</u>	Div. B / 3.2.4.	Permit the use of a residential warning system in lieu of an interconnected smoke alarm system.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-02-02</u>	Div. B / 3.2.4.8.(1)	This editorial change to the occupancies that are required to send a signal to the fire department is necessary as a result of the new occupancy definitions in the Code.	Retirement Homes	Ontario
<u>R-B-03-02-03</u>	Div. B / 3.2.4.9.(2)	Require that fire alarm annunciator panel is accurately zoned to display all fire compartments in the retirement home.	Retirement Homes	Ontario
<u>R-B-03-02-04</u>	Div. B / 3.2.4.13.(1)	Amend requirements to limit smoke from a fire in one fire compartment from circulating throughout the building.	Retirement Homes	Ontario
<u>R-B-03-02-05</u>	Div. B / 3.2.4.18.(6)	Permission to install manual pull station in dwelling unit does not apply to retirement homes. (current provision applies to “apartment” buildings).	Retirement Homes	Ontario
<u>R-B-03-02-06</u>	Div. B / 3.2.4.22.	Require that smoke alarms in suites of a retirement home provide an audible and visual signal to staff serving those suites.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-02-08</u>	Div. B / 3.2.4.22.(6)	Permit smoke detectors in lieu of smoke alarms provided they sound audible signals within individual suites.	Fire Safety	Ontario
<u>B-03-02-09</u>	Div. B / 3.2.4.22.(6)	Clarify that, in suites of residential occupancy, where a smoke detector is permitted to be substituted for a smoke alarm, it is required to be equipped with a visual signalling device.	Fire Safety	Ontario
<u>B-03-02-10</u>	Div. B / 3.2.4.22.(13)	Add an appendix note to clarify issues related seizures that may be triggered as a result of exposure to multiple unsynchronized flashing signals in a dwelling.	Fire Safety	Ontario
<u>B-03-02-11</u>	Div. B / 3.2.4.23.	Amend the intelligibility level of voice communication systems from a mandatory target to a voluntary target level with guidance.	Fire Safety	mNBC
<u>B-03-02-12</u>	Div. B / 3.2.4.23.(5)	Introduces a requirement that visual signals not be interrupted during a voice communication transmission.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-02-07</u>	Div. B / 3.2.4.23.	Revise Sentence 3.2.4.23.(1) to specify the requirements for a voice communication system to be installed in a retirement home.	Retirement Homes	Ontario
<u>R-B-03-02-08</u>	Div. B / 3.2.5.13.(2)	Maintain adequate fire detection for residents of a retirement home.	Retirement Homes	Ontario
<u>R-B-03-02-09</u>	Div. B / 3.2.5.13.(9)	This editorial change is necessary as a result of the new defined term "retirement home".	Retirement Homes	Ontario
<u>B-03-02-13</u>	Div. B / 3.2.5.14.(1)	Clarify the use of combustible sprinkler piping in conformance with their listings and manufacturers' installation instructions that meets the requirements of ULC/ORD-1999P, "Combustible Piping for Sprinkler Systems".	Fire Safety	mNBC
<u>B-03-02-14</u>	Div. B / 3.2.5.19.(1)	Fire Pump should meet NFPA 20 regardless of head pressure.	Fire Safety	Ontario
<u>R-B-03-02-10</u>	Div. B / 3.2.6.1.(1)	Revise the application of high building requirements to include retirement homes as an equivalent of care occupancies.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-02-15</u>	Div. B / 3.2.6.2.(6)	Require that smoke movement be limited in high-rise Group C occupancy buildings.	Fire Safety	mNBC
<u>B-03-02-16</u>	Div. B / 3.2.6.7.(2)	Clarify which smoke management systems are targeted by Clause 3.2.6.7.(2)(i).	Fire Safety	mNBC
<u>R-B-03-02-11</u>	Div. B / 3.2.6.8.(1)	Delete the requirement for a voice communication system in a retirement home that is a high building since all retirement homes will now require a voice communication system (refer to new Article 3.3.4.11.) The reference to the high building requirement is redundant.	Retirement Homes	Ontario
<u>R-B-03-02-12</u>	Div. B / 3.2.7.1.(1)	Revise Sentence 3.2.7.3.(1) to extend current requirements for lighting levels to apply to retirement homes where care is provided.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-02-17</u>	Div. B / 3.2.7.3.(1)	<p>Add a new Sentence to address emergency lighting for rooftop occupancies.</p> <p>Require emergency lighting in barrier-free washrooms, in universal washrooms and in public washrooms that serve more than one person at a time.</p>	Fire Safety	Ontario
<u>R-B-03-02-13</u>	Div. B / 3.2.7.3.(1)	Revise Sentence 3.2.7.3.(1) to extend current requirements for emergency lighting levels to apply to retirement homes.	Retirement Homes	Ontario
<u>R-B-03-02-14</u>	Div. B / 3.2.7.4.(1)	Revise Sentence 3.2.7.4.(1) to extend current requirements for emergency power for lighting to apply to retirement homes.	Retirement Homes	Ontario
<u>R-B-03-02-15</u>	Div. B / 3.2.7.8.(3)	Revise Sentence 3.2.7.8.(3) to extend current requirements for emergency power for fire alarms to apply to retirement homes.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-02-18</u>	Div. B / 3.2.7.9.(1).	Introduce a cross-reference to Article 3.3.3.6. ensuring that air handling equipment supplying areas of refuge and contained use areas are connected to the emergency power supply of a building.	Fire Safety	mNBC
<u>B-03-02-19</u>	Div. B / 3.2.7.10.	Introduce protection measures for the distribution panel controlling the emergency lighting in a building and introduce an appendix note clarifying the application of the referenced CAN/ULC-S139 standard for electrical conductors.	Fire Safety	mNBC
<u>R-B-03-02-16</u>	Div. B / 3.2.8.1.(3)	Revise Sentence 3.2.8.1.(3) to extend current prohibitions of occupancies that may not be constructed as part of an interconnected floor space to retirement homes.	Retirement Homes	Ontario
<u>B-03-02-20</u>	Div. B / 3.2.8.2.(1)	Clarify that the maximum permitted area of the mezzanine is 500 square metres, regardless of the occupancy, in order to be exempt from the fire separation requirements.	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-02-17</u>	Div. B / 3.2.8.6.(1)	Revise Sentence 3.2.8.6.(1) to provide appropriate measures to restrict smoke movement in a retirement home that contains an interconnected floor space.	Retirement Homes	Ontario
<u>B-03-02-21</u>	Div. B / 3.2.9.1.(1)	Revise Sentence to clarify the requirements for Standpipe Systems.	Fire Safety	Ontario
<u>B-03-02-22</u>	Div. B / 3.2.9.1.(8)	Add an exemption from standpipe requirement for stacked townhouses.	Fire Safety	Ontario
<u>B-03-02-23</u>	Div. B / 3.2.9.2.(6)	Amend head pressure from "greater than 280 kPa" to "equal or greater than 275 kPa" due to a conversion error from imperial to metric.	Fire Safety	Ontario
<u>B-03-03-01</u>	Div. B / 3.3.1.2.(1)	Clarify provisions for hazardous substances related to the proposed revision of the definition for dangerous goods which includes classified controlled products under the Workplace Hazardous Materials Information System (WHMIS).	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-03-01</u>	Div. B / 3.3.1.5.(1)	Revise Table 3.3.1.5.(1) to extend appropriate room/suite size threshold for second egress doorway to retirement homes.	Retirement Homes	Ontario
<u>B-03-03-02</u>	Div. B / 3.3.1.7.	Delete the reference to weatherstripping for doors acting as closures in a fire separation.	Fire Safety	mNBC
<u>B-03-03-03</u>	Div. B / 3.3.1.7.	Clarify that the floor area on either side of a horizontal exit is permitted to be considered as a zone for the application of Article 3.3.1.7.	Fire Safety	mNBC
<u>R-B-03-03-02</u>	Div. B / 3.3.1.9.	Provides appropriate provisions for corridors in retirement homes.	Retirement Homes	Ontario
<u>B-03-03-04</u>	Div. B / 3.3.1.10.	Harmonize the Part 3 and Part 9 provisions regarding the use of sliding doors as access-to-exit and exit doors. This permission is limited to small area storage rooms.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-03-03</u>	Div. B / 3.3.1.10.(3)	Add new Clause (e) to Sentence 3.3.1.10. to maintain current door swing provisions applicable to retirement homes where care is provided.	Retirement Homes	Ontario
<u>R-B-03-03-04</u>	Div. B / 3.3.1.12.(1) Div. B / 3.3.1.12.(4)	Provide appropriate doorway widths and the current prohibition disallowing additional door release hardware applicable to retirement homes where care is provided.	Retirement Homes	Ontario
<u>B-03-03-05</u>	Div. B / 3.3.1.12.(1) Div. B / 3.4.6.11.	Set a limit on the height of a door threshold, other than in a required barrier-free path of travel.		mNBC
<u>B-03-03-06</u>	Div. B / 3.3.1.13.	Revise Article 3.3.1.13. to clarify the requirements that are applicable to stairs other than exit stairs. A corresponding change has been made to Sentence 3.4.6.2.(1) .	Stairs, Guards & Handrails	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-03-07</u>	Div. B / 3.3.1.15.	This proposed change, along with the changes to Article 9.8.4.3. in Part 9 introduces consistent terminology and states the proper way of constructing tapered treads in other than required exit stairs in Part 3 and Part 9 buildings.	Stairs, Guards & Handrails	mNBC
<u>B-03-03-08</u>	Div. B / 3.3.1.16. Div. B / 3.4.2.6.	Require that the main entrance to bars and night clubs count for at least half of the occupant load.	Fire Safety	mNBC
<u>R-B-03-03-05</u>	Div. B / 3.3.1.16.(4)	Extend current determinants used to calculate the required width of corridors, doorways, and ramps to apply to retirement homes.	Retirement Homes	Ontario
<u>B-03-03-09</u>	Div. B / 3.3.1.17.	Clarify Part 3 requirements where the elevated walking surface is adjacent to a sloped ground and harmonize with Part 9 requirements. It also harmonizes Part 3 and Part 9 regarding maintenance platforms.		mNBC
<u>B-03-03-10</u>	Div. B / 3.3.1.17.	Establish requirements for guards at skylights.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-03-11</u>	Div. B / 3.3.1.18.	Set requirements for the maximum height for the lowest edge of transparent glazing panels and the design and location criteria for markings on transparent glazing.		mNBC
<u>B-03-03-12</u>	Div. B / 3.3.1.19.	Require that a duct of an exhaust ventilation system handling contaminants with a potential to create a fire or explosion hazard be enclosed when penetrating a fire separation required to have a fire-resistance rating.	Fire Safety	mNBC
<u>B-03-03-13</u>	Div. B / 3.3.2. Div. B / 3.4.6.5.	Introduce requirements for the installation of handrails in aisles with steps in assembly occupancies.	Stairs, Guards & Handrails	mNBC
<u>B-03-03-14</u>	Div. B / 3.3.3.5.	Delete the reference to weather stripping for doors acting as closures in a fire separation	Fire Safety	mNBC
<u>R-B-03-03-06</u>	Div. B / 3.3.3.4.(1)	Revise the Article to clarify the location where 1050 mm wide doors are required.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-03-07</u>	Div. B / 3.3.4.2.	Extend current provisions for fire separation requirements to those between retirement homes and storage garages.	Retirement Homes	Ontario
<u>R-B-03-03-08</u>	Div. B / 3.3.4.4.(2)	Provide appropriate egress provisions from dwelling units in retirement homes.	Retirement Homes	Ontario
<u>B-03-03-15</u>	Div. B / 3.3.4.6.	Make the signpost in Article 3.3.4.6. to the sound transmission requirements consistent with proposed wording in Section 5.9.	Sound Transmission	mNBC
<u>B-03-03-16</u>	Div. B / 3.3.4.7.(2) Div. B / 3.3.4.7.(3)	Replace "single dwelling unit" with <i>house</i> in Sentences 3.3.4.7.(2) & (3).	Secondary Suites	Ontario
<u>R-B-03-03-09</u>	Div. B / 3.3.4.11.	Add new Article 3.3.4.11. to provide adequate safety measures for occupants and staff of a retirement home.	Retirement Homes	Ontario
<u>B-03-03-17</u>	Div. B / 3.3.5.4.	Clarify the requirements for vehicle guardrails in storage garages.		mNBC
<u>R-B-03-03-10</u>	Div. B / 3.3.5.7.(1)	Maintain the requirement for a vestibule between a retirement home and a storage garage.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-03-18</u>	Div. B / 3.3.5.7.(3)	Address vestibule protection with restrictions to openings.	Fire Safety	Ontario
<u>B-03-03-19</u>	Div. B / 3.3.5.	Introduce a new provision for guards located in industrial occupancies.	Stairs, Guards & Handrails	mNBC
<u>B-03-03-20</u>	Div. B / 3.3.6.2.	<p>Replace the term "reactive substances" with "reactive materials" and provides clarification on the associated hazards.</p> <p>It also replaces the Transportation of Dangerous Goods Regulations (TDGR) classification of Classes 1 and 5 dangerous goods with the new descriptor for explosives and oxidizing substances.</p>	Fire Safety	mNBC
<u>R-B-03-04-01</u>	Div. B / 3.4.2.1.	Provides an appropriate number of exits for a floor area of a retirement home.	Retirement Homes	Ontario
<u>R-B-03-04-02</u>	Div. B / 3.4.3.2.(1) Div. B / 3.4.3.2.(2)	Extend provisions for the appropriate calculation of the minimum aggregate required width of exits serving floor areas to retirement homes.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-04-01</u>	Div. B / 3.4.2.3.	Introduce a minimum distance between the exterior discharge points of exits.	Fire Safety	mNBC
<u>B-03-04-02</u>	Div. B / 3.4.3.4.(4)	Editorial change to make wording consistent with Part 9 requirement on exit width reduction.	Fire Safety	mNBC
<u>B-03-04-03</u>	Div. B / 3.4.5.1.	Clarifies the Code intent regarding referenced standards for exit signage.	Fire Safety	mNBC
<u>B-03-04-04</u>	Div. B / 3.4.6.1.	Clarify that TWSI per 3.8.3.18. needs to be at the top of a ramp not just a strip along the leading edge.	Accessibility	Ontario
<u>B-03-04-05</u>	Div. B / 3.4.6.2.(1)	Revise Sentence 3.4.6.2.(1) in order to limit the application to exit stairs. A corresponding change to Article 3.3.1.13. will clarify the requirements that are applicable to stairs other than exit stairs.	Stairs, Guards & Handrails	Ontario
<u>B-03-04-06</u>	Div. B / 3.4.6.4.	Amend requirements for consistency of landing dimensions serving stairs in Part 3 and Part 9.	Stairs, Guards & Handrails	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-04-07</u>	Div. B / 3.4.6.5.	<p>Clarify the graspable continuity of a handrail throughout the length of a ramp and stair flight and clarify where handrails are required.</p> <p>This proposed change relocates the structural loading requirements for handrails and handrail supports requirements to Part 4 from Part 3.</p> <p>Delete requirement for 300 mm horizontal handrail extension.</p>	Stairs, Guards & Handrails	mNBC
<u>R-B-03-04-03</u>	Div. B / 3.4.6.5.(14)	Require that stairways serving a retirement home are provided with continuous handrails on both sides.	Retirement Homes	Ontario
<u>B-03-04-08</u>	Div. B / 3.4.6.6.(1) Div. B / 3.4.6.6.(2) Div. B / 3.4.6.6.(3)	Harmonize Part 3 and Part 9 requirements regarding guard height serving a flight of exit stairs.	Stairs, Guards & Handrails	mNBC
<u>B-03-04-09</u>	Div. B / 3.4.6.7.	Amend the ramp slope for mercantile occupancies to 1 in 8.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-04-10</u>	Div. B / 3.4.6.8.	<p>Change Rise and Run to match public stairs in 9.8.4.1.</p> <p>This proposed change clarifies that mixed run flights of stairs are not permitted in Part 3 buildings.</p> <p>Address restrictions on the use of open stair risers.</p> <p>Amend stair run depth to be maximum no limit, to be consistent with corresponding provision in 2010 mNBC Part 3, and 2010 mNBC Table 9.8.4.1. and 2012 OBC Table 9.8.4.1.</p>	Stairs, Guards & Handrails	mNBC
<u>B-03-04-11</u>	Div. B / 3.4.6.9.	Clarify the permitted configurations for exit stairs in Part 3 buildings.	Stairs, Guards & Handrails	mNBC
<u>B-03-04-12</u>	Div. B / 3.4.6.11.	Require signs that warn people where parking and storage may obstruct the exterior exit doors and are prohibited.		mNBC
<u>R-B-03-04-04</u>	Div. B / 3.4.6.16.(4).	Clarify that magnetic locks on exit doors of a retirement home must release upon activation of an alarm signal of a two stage fire alarm system.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-04-05</u>	Div. B / 3.4.6.16.(6)	Permit electromagnetic locks to be installed on an exterior door leading from an exit stairway in a building serving a retirement home.	Retirement Homes	Ontario
<u>B-03-04-13</u>	Div. B / 3.4.6.18	Clarify provisions for emergency access to crossover floor areas.	Fire Safety	mNBC
<u>R-B-03-04-06</u>	Div. B / 3.4.7.1.(2)	Prohibit the installation of a fire escape on a retirement home.	Retirement Homes	Ontario
<u>B-03-06-01</u>	Div. B / 3.6.1.5. SB-8	Add requirements for anchor points for portable ladders on buildings of specified heights.		Ontario
<u>R-B-03-06-01</u>	Div. B / 3.6.2.9.(1)	Extend the requirement that oxygen containers are stored in a fire separated room to apply to a retirement home.	Retirement Homes	Ontario
<u>B-03-06-02</u>	Div. B / 3.6.3.	Clarify that the fire-resistance rating of factory-built and field-applied grease duct enclosures need to comply with the new referenced standard CAN/ULC-S144 "Standard Method of Fire Resistance Test-Grease Duct Assemblies".	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-06-03</u>	Div. B / 3.6.4.3. Div. B / 9.10.13.14.(1) SB-2	Replaces references to SB2 with a reference to CAN/ULC-S112.2, "Standard Method of Fire Test of Ceiling Firestop Flap Assemblies".	Fire Safety	mNBC
<u>R-B-03-07-01</u>	Div. B / 3.7.1.3.(1)	Require that sufficient living space is provided for residents of retirement homes.	Retirement Homes	Ontario
<u>B-03-07-01</u>	Div. B / 3.7.4.2.(5)	Amend to require a lavatory to serve not more than 2 water closets or urinals.		Ontario
<u>B-03-07-02</u>	Div. B / 3.7.4.2.(7)	Clarify where a universal washroom may be used to reduce the plumbing fixture count.	Accessibility	Ontario
<u>B-03-07-03</u>	Div. B / 3.7.4.2.(9)	Sentence 3.7.4.2.(9) should be part of Article 3.7.4.3. since it relates only to some A2 occupancy types.		Ontario
<u>B-03-07-04</u>	Div. B / 3.7.4.2.(11)	Clarify requirements for types of faucets serving lavatories.		mNBC
<u>R-B-03-07-02</u>	Div. B / 3.7.4.4.(2) Div. B / 3.7.4.4.(3)	Require sufficient sanitary facilities for residents and staff of retirement homes.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-07-05</u>	Div. B / 3.7.4.5.(2)	Add requirement for laundry facilities.		Ontario
<u>B-03-07-06</u>	Div. B / 3.7.5.2.	Include requirements of Ontario's Fire Code or Part 3 of the National Fire Code of Canada to address the additional fire safety concern related to the design and installation of medical gas piping.	Fire Safety	mNBC
<u>B-03-07-07</u>	Div. B / 3.7.4.13.(1)	Add new appendix note to 3.7.4.13.(1) to explain the meaning of 'automatic' with respect to flushing devices.		Ontario
<u>B-03-07-08</u>	Div. B / 3.7.4.16.(2)	Replace 'private use' with 'individual use'.		Ontario
<u>B-03-08-01</u>	Div. B / 3.8.1.1.(1)	Revise Clause 3.8.1.1.(1)(a) to simplify residential exemptions due to new definition of <i>house</i> .	Secondary Suites	Ontario
<u>B-03-08-02</u>	Div. B / 3.8.1.3.	Add a requirement for maximum cross-slope in a barrier-free path of travel and adds an appendix note to address surfaces in a barrier-free path of travel.	Accessibility	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-08-03</u>	Div. B / 3.8.1.5.	Amend and clarify all common criteria for accessible controls related to the operation of building services and safety devices.	Accessibility	mNBC
<u>R-B-03-08-01</u>	Div. B / 3.8.2.1.(2)	Provide an appropriate barrier free path of travel for residents of retirement homes.	Retirement Homes	Ontario
<u>B-03-08-04</u>	Div. B / 3.8.2.1.(5) Div. B / 3.8.2.1.(7)	Add combined living/sleeping area to Sentence (5) and add studio or bachelor apartments to list of unit types to be barrier-free in Sentence (7).	Accessibility	Ontario
<u>B-03-08-05</u>	Div. B / 3.8.2.1.(6)	Add Code reference for 9.5.2.3.(1) for grab bar wall reinforcement.	Accessibility	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-08-06</u>	Div. B / 3.8.2.3.(2)	Propose an alternate method of determining the minimum number of universal washrooms conforming to 3.8.3.12. using the building area to result in a more proportionate ratio of universal washrooms that relates to the size and use of each building and clarify that universal washrooms are not required on storeys that contain only residential suites or storage garages.	Accessibility	Ontario
<u>B-03-08-07</u>	Div. B / 3.8.2.3.(3)	Clarify requirements for barrier-free washrooms.	Accessibility	Ontario
<u>B-03-08-08</u>	Div. B / Table 3.8.2.3.A	Correct requirements in Table 3.8.2.3.A regarding the number of universal washrooms required in buildings 6 storeys or more.	Accessibility	Ontario
<u>B-03-08-09</u>	Div. B / 3.8.3.1.(4)	Change <i>barrier-free means of egress</i> back to <i>accessible means of egress</i> .	Accessibility	Ontario
<u>R-B-03-08-02</u>	Div. B / 3.8.3.3.(2)	Provide an appropriate barrier free path of travel for residents of retirement homes.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-08-03</u>	Div. B / 3.8.3.3.(4) Div. B / 3.8.3.3.(5) Div. B / 3.8.3.3.(6)	Provide an appropriate barrier free path of travel for residents of retirement homes.	Retirement Homes	Ontario
<u>B-03-08-10</u>	Div. B / 3.8.3.3.(4) Div. B / 3.8.3.3.(5) Div. B / 3.8.3.3.(6)	Refer to power door operator <u>controls</u> .	Accessibility	Ontario
<u>B-03-08-11</u>	Div. B / 3.8.3.3.(10)	Revise latch side clearances for sliding doors.	Accessibility	Ontario
<u>B-03-08-12</u>	Div. B / 3.8.3.3.(16) Div. B / 3.8.3.3.(17)(d)	Clarify location requirements for power door operator controls.	Accessibility	Ontario
<u>B-03-08-13</u>	Div. B / 3.8.3.4.(1)(g)	Clarify curb requirements along the sides of barrier-free ramps.	Accessibility	Ontario
<u>B-03-08-14</u>	Div. B / 3.8.3.8.(1)	This proposed change provides additional requirements clarifying the intent for accessibility for water closet stalls in a washroom required to be barrier-free.	Accessibility	mNBC
<u>B-03-08-15</u>	Div. B / 3.8.3.8.(7) Div. B / 3.8.3.8.(8)	Amend the diameter range of the grab bar from 35 mm to 40 mm to 30 mm to 40 mm.	Accessibility	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-08-16</u>	Div. B / 3.8.3.9.	Provide additional clarification on accessibility requirements for water closets.	Accessibility	mNBC
<u>B-03-08-17</u>	Div. B / 3.8.3.10.	Provide additional clarification on accessibility requirements for urinals located in a barrier-free washroom.	Accessibility	mNBC
<u>B-03-08-18</u>	Div. B / 3.8.3.11.	Provide additional clarification on accessibility requirements for lavatories located in a barrier-free washroom or universal washroom.	Accessibility	mNBC
<u>B-03-08-19</u>	Div. B / 3.8.3.12.	Provide additional clarification on accessibility requirements for universal toilet rooms.	Accessibility	mNBC
<u>B-03-08-20</u>	Div. B / 3.8.3.12.(6)	Require emergency lighting in universal washrooms	Accessibility	Ontario
<u>R-B-03-08-04</u>	Div. B / 3.8.3.13.(3) Div. B / 3.8.3.13.(4)	Provide appropriate barrier-free bathing facilities for residents of a retirement home.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-08-21</u>	Div. B / 3.8.3.13.(4) Div. B / 3.8.3.13.(5)	Amend requirements for grab bars, faucets, hand-held shower head and clear floor space for bathtubs only for Group B, Division 2 or 3 occupancies.	Accessibility	mNBC
<u>B-03-08-22</u>	Div. B / 3.8.3.13.	State that no doors or curtains shall obstruct controls or transfer space. Permit a vertical threshold no more than 7mm. Require additional grab bars to maintain a safe balance.	Accessibility	mNBC
<u>B-03-08-23</u>	Div. B / 3.8.3.18.(2)	Amend the tactile walking surface indicators depth to be not less than 610 mm.	Accessibility	Ontario
<u>B-03-11-01</u>	Div. B / 3.11.3.1.(9)(a)	Clarify that there needs to be a minimum of 1100 mm between a column or wall and pool edge (formerly 900 mm) but the 1100 mm is to be provided within the 1800 mm pool deck not in addition to the 1800 mm wide deck.	Accessibility	Ontario
<u>B-03-11-02</u>	Div. B / 3.11.3.1.(14)	Amend Sentence (14) to clarify that the tactile indicator is to be located at the edge of the pool not anywhere within the pool deck.	Accessibility	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-11-03</u>	Div. B / 3.11.5.1.(4)(b)	Amend width opening to ramp at pool deck to be the same as the ramp width - not the current 750 mm.	Accessibility	Ontario
<u>R-B-03-11-01</u>	Div. B / 3.11.5.2.(1)	This proposed change to Sentence 3.11.5.2.(1) provides a sufficient length of the pool perimeter for the installation of a ramp serving a public pool in a retirement home.	Retirement Homes	Ontario
<u>B-03-13-01</u>	Div. B / 3.13.2.1.(7) Div. B / 3.13.2.1.(8) Div. B / 3.13.2.1.(9)	<p>This change to Article 3.13.2.1. permits an interconnected floor space and an unenclosed elevator hoistway in a rapid transit station, provided certain conditions are met.</p> <p>The change also rationalizes existing provisions of the Article.</p> <p>Clarify requirements for interconnection of station levels.</p> <p>Permit the location of passenger elevators within or adjacent to interconnected floor spaces in stations.</p> <p>Permit interconnection of station levels subject to performance goals.</p>	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-13-02</u>	Div. B / 3.13.3.6.(5) Div. B / 3.13.3.6.(6)	Revise existing Sentences 3.13.3.6.(5) and (6) to clarify the vestibule shall be protected against passage of smoke in accordance with Measure N of Supplementary Standard SB-4, "Measures for Fire Safety in High Buildings".	Fire Safety	Ontario
<u>B-03-13-03</u>	Div. B / 3.13.3.8.	Add a new Article to Subsection 3.13.3. that clarifies that guards for rapid transit stations are not required along the guideway side of train platform.		Ontario
<u>B-03-13-04</u>	Div. B / 3.13.4.2.(5) Div. B / 3.13.4.2.(6) Div. B / 3.13.4.2.(7)	Exempt platform edge adjacent to guideways from the requirement for guards. Revise Article 3.13.4.2. to permit an emergency ventilation system in lieu of a protected egress route in a rapid transit station. Clarify intent for measures for emergency ventilation to achieve performance goals.	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-13-05</u>	Div. B / 3.13.4.5.(4) Div. B / 3.13.4.5.(5) Div. B / 3.13.4.5.(6) Div. B / 3.13.4.5.(7) Div. B / 3.13.4.5.(9)	<p>This change to Article 3.13.4.5. revises the minimum permitted width of a means of egress and reduces the minimum permitted width of platforms.</p> <p>Amend minimum widths for egress facilities and permit alternate designs where additional capacity is provided.</p> <p>Delete redundant Sentence related to means of egress.</p> <p>Permit escalators not moving in direction of egress to be counted as stairs.</p> <p>Amend clear platform widths</p> <p>Delete minimum platform widths.</p> <p>Other minimum widths related to egress, barrier-free design still apply.</p>	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-13-06</u>	Div. B / 3.13.4.6.(1)	<p>Revise Sentence 3.13.4.6.(1) to permit an unlimited vertical rise for escalators forming part of a required means of egress.</p> <p>Delete maximum vertical rise of escalators between floors and landings for greater flexibility in space planning of stations.</p>		Ontario
<u>B-03-13-07</u>	Div. B / 3.13.5.10.(2)	Delete Sentence 3.13.5.10.(2) in order not to require the sprinkling of the steel truss enclosure of an escalator serving a rapid transit station.	Fire Safety	Ontario
<u>B-03-15-01</u>	Div. B / 3.15.4.1.(1)(b)	<p>Revise the testing standard for "Rate of Burning and/or Extent and Time of Burning of Flexible Plastics in Vertical Position".</p> <p>Remove reference to ASTM D568 testing standard for Combustible Sign Faces and Permit plastic sign materials to be tested in compliance with ASTM D635 or ASTM D3801.</p>	Fire Safety	Ontario
<u>B-03-15-02</u>	Div. B / 3.15.5.2.(4)	Harmonize requirements for distance of electrical conductor from exterior signs with the Ontario Electrical Safety Code.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-03-17-01</u>	Div. B / 3.17.1.1.(1)	Revise Sentence 3.17.1.1.(1) related to application as a result of the new defined term <i>retirement home</i> .	Retirement Homes	Ontario
<u>B-03-18-01</u>	Div. B / 3.18.1.1.	Create a new Section 3.18 that contains stand-alone provisions for Demountable Event Structures (Temporary Stages). Article 3.18.1.1. defines the scope of these structures.	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-03-18-02</u>	Div. B / 3.18.2.1.	Include a new Sentence that defines the occupant load for the demountable event structure.	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-03-18-03</u>	Div. B / 3.18.2.2.	Section 3.18. is a stand-alone Section applicable to Demountable Event Structures (Temporary Stages). For this reason a new Article 3.18.2.2. has been added to include provisions for means of egress.	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-03-18-04</u>	Div. B / 3.18.2.3.	Include provisions for guards applicable to Demountable Event Structures (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-18-05</u>	Div. B / 3.18.2.4.	Include new provisions for clearances to other structures, applicable to Demountable Event Structures (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-03-18-06</u>	Div. B / 3.18.2.5.	Include a provision for the flame resistance of tarpaulins, decorative materials, fabrics and films used in connection with Demountable Event Structures (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-03-18-07</u>	Div. B / 3.18.2.6.	Include a provision for firefighting access applicable to Demountable Event Structures (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-03-18-08</u>	Div. B / 3.18.2.7.	Include a provision for electrical installations related to Demountable Event Structures (Temporary Stages) that are not covered under the Ontario Electrical Safety Code.	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-03-18-09</u>	Div. B / 3.18.2.8.	Include specific structural provisions for Demountable Event Structures (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-03-18-10</u>	Div. B / 3.18.2.9.	Include specific barrier-free provisions for Demountable Event Structures (Temporary Stages).	Demountable Event Structures (Temporary Stages)	Ontario
<u>B-04-01-01</u>	Div. B / 4.1.2.1.(3)	Exempt private schools from requirements to be constructed as post-disaster buildings.	Structural Integrity	Ontario
<u>B-04-01-02</u>	Div. B / 4.1.3.2.	Address a perceived safety concern with the current approach to the live load plus snow load combination.	Structural Integrity	mNBC
<u>B-04-01-03</u>	Div. B / 4.1.5.14.(1) Div. B / 4.1.5.15.(1)	Clarify that where point loads for guards are specified, the design is to take into account the points of application that produce the most critical effect.	Structural Integrity	mNBC
<u>B-04-01-04a</u>	Div. B / 4.1.5.14.(2)	Reduce the inward guard live loads to half that of the outward guard live loads.	Structural Integrity	mNBC
<u>B-04-01-04b</u>	Div. B / 4.1.5.14.(2)	Clarify that the panel load for guards is to be applied outward.	Structural Integrity	mNBC
<u>B-04-01-05</u>	Div. B / 4.1.5.14.(3)	Introduce deflection limits for guard pickets.	Structural Integrity	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-04-01-06</u>	Div. B / 4.1.5.14.(5)	Transfer the loads for handrails from Part 3 to Part 4 of the Building Code.	Structural Integrity	mNBC
<u>B-04-01-07</u>	Div. B / 4.1.5.15.	Clarify that the vehicle guardrail loads do not need to be applied concurrently with the guard loads for the purpose of design.	Structural Integrity	mNBC
<u>B-04-01-08</u>	Div. B / 4.1.5.16.(1)	Revise the design lateral live load of walls, where they act as guards to act in an outward direction only.	Structural Integrity	mNBC
<u>B-04-01-09</u>	Div. B / 4.1.6.2. Div. B / 4.1.6.	Harmonize for loads due to snow and rain requirements with the mNBC.	Structural Integrity	mNBC
<u>B-04-01-10</u>	Div. B / 4.1.6.2.(2)	Revise the basic roof snow load factor to tie it to the wind exposure in addition to the roof size.	Structural Integrity	mNBC
<u>B-04-01-11</u>	Div. B / 4.1.7.	Harmonize wind load requirements with the mNBC.	Structural Integrity	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-04-01-12</u>	Div. B / 4.1.8.1.	Introduce a simple and easily applied methodology to design for very low force levels in low hazard, low risk earthquake zones, and provide minimum levels of lateral strength and toughness in buildings and to remove the trigger exempting the application of the seismic design Subsection.	Structural Integrity	mNBC
<u>B-04-01-13</u>	Div. B / 4.1.8.	Add requirements for seismically isolated structures (sometimes also referred to as base isolated structures).	Structural Integrity	mNBC
<u>B-04-01-14</u>	Div. B / 4.1.8.	Add requirements for structures with supplementary energy dissipation systems (sometimes also referred to as supplemental damping).	Structural Integrity	mNBC
<u>B-04-01-15</u>	Div. B / 4.1.8.2. Div. B / 4.1.8.4. Div. B / 4.1.8.18.	This proposed change captures changes to Articles 4.1.8.2., 4.1.8.4. and 4.1.8.18. required as a result of an update to the seismic hazard model.	Structural Integrity	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-04-01-16</u>	Div. B / Table 4.1.8.9.	Add an appendix note to direct the Code user to CSA S16 'Design of Steel Structures' for guidance on system restrictions and requirements for seismic design of industrial type steel structures.	Structural Integrity	mNBC
<u>B-04-01-17</u>	Div. B / Table 4.1.8.9.	Revise the masonry structural systems in the seismic design Subsection to be compatible with the CSA S304 referenced standard.	Structural Integrity	mNBC
<u>B-04-01-18</u>	Div. B / Table 4.1.8.9.	Revise the concrete structural systems in the seismic design Subsection to be compatible with the CSA A23.3-14 referenced standard.	Structural Integrity	mNBC
<u>B-04-01-19</u>	Div. B / Table 4.1.8.9.	Clarify the height restrictions for the seismic-force resisting systems (SFRS) in buildings.	Structural Integrity	mNBC
<u>B-04-01-20</u>	Div. B / 4.1.8.10. Div. B / 4.1.8.6.	Add seismic design requirements for buildings with gravity-induced lateral demands on the structural system resisting the seismic loads.	Structural Integrity	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-04-01-21</u>	Div. B / Table 4.1.8.11.	Add requirements for the calculation of the period of a building with a flexible roof diaphragm for use in seismic design.	Structural Integrity	mNBC
<u>B-04-01-22</u>	Div. B / 4.1.8.11.	Revise the values of higher mode factors M_v and J for use with uniform hazard spectra based on Trial 3E hazard model used by the mNBC.	Structural Integrity	mNBC
<u>B-04-01-23</u>	Div. B / 4.1.8.11.(2)	Revise the static procedure of seismic design to be compatible with the new hazard values.	Structural Integrity	mNBC
<u>B-04-01-24</u>	Div. B / 4.1.8.12.(6)	Revise the seismic cap for the dynamic procedure to be compatible with the new hazard values.	Structural Integrity	mNBC
<u>B-04-01-25</u>	Div. B / 4.1.8.13.(2)	Add a requirement to the calculation of displacements to include increases due to foundation movements.	Structural Integrity	mNBC
<u>B-04-01-26</u>	Div. B / 4.1.8.15.	Add seismic design provisions for structures with flexible roof diaphragms.	Structural Integrity	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-04-01-27</u>	Div. B / 4.1.8.16.	Provide clarification on the application of site class amplification/ de-amplification for liquefaction studies.	Structural Integrity	mNBC
<u>B-04-01-28</u>	Div. B / 4.1.8.17.(1)	Provide clarification on the application of site class amplification/ de-amplification for slope stability studies.	Structural Integrity	mNBC
<u>B-04-01-29</u>	Div. B / 4.1.8.18.	Add an appendix note to direct the Code user to the CSA S832 'Seismic Risk Reduction of Operational and Functional Components (OFCs) of Buildings' for guidance on elements not addressed in Subsection 4.1.8.	Structural Integrity	mNBC
<u>B-04-01-30</u>	Div. B / 4.1.8.18.	Add requirements for the seismic effects and anchorage for steel pallet storage racks.	Structural Integrity	mNBC
<u>B-04-01-31</u>	Div. B / 4.1.8.18.	Introduce requirements for seismic design and anchorage of elevators and escalators.	Structural Integrity	mNBC
<u>B-04-01-32</u>	Div. B / Table 4.1.8.18. Div. B / 4.1.8.18.(8)	Remove conflicting duplications from the Table for seismic design of portions of buildings.	Structural Integrity	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-04-01-33</u>	Div. B / 4.1.8.18.(14) Div. B / 4.1.8.18.(15)	Add a requirement to consider the effects of building lateral earthquake displacements on glazing systems.	Structural Integrity	mNBC
<u>B-04-03-01</u>	Div. B / 4.3.6.1.	Add a reference to ASTM E-1300 "Standard Practice for Determining Load Resistance of Glass in Buildings", using an adjustment factor on the wind load for structural glass.	Structural Integrity	mNBC
<u>B-04-04-01</u>	Div. B / 4.4.2.1.	Replace the term "parking structure" with the defined term "storage garage" and require that repair garages meet minimum corrosion protection standards.	Structural Integrity	mNBC
<u>B-04-04-02</u>	Div. B / 4.4.4.1.	Amend requirements for roof anchors.		Ontario
<u>B-05-01-01</u>	Div. B / 5.1.4.1.	Clarify that materials, components and assemblies fulfilling multiple functions are required to satisfy all the intended functions.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-05-02-01</u>	Div. B / 5.2.2.1.	Add an additional appendix note to the existing A-5.2.2.1.(2)(c) that addresses earthquake effects in the seismic design of post-disaster buildings.		mNBC
<u>B-05-02-02</u>	Div. B / 5.2.2.2.	Add new Sentence to require wind uplift resistance of roofing assemblies to meet CSA A123.21 "Standard test method for the dynamic wind uplift resistance of membrane roofing systems".		mNBC
<u>B-05-03-01</u>	Div. B / 5.3.1.2.	Clarify that products meeting the requirements of the harmonized standard for air, water and structural do not necessarily meet the condensation level needed for a given project. Add an appendix note that addresses physical testing of condensation resistance consistent with CAN/CSA-A440.2. "NAFS-North American Fenestration Standard/Specification for Windows, Doors, and Skylights".		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-05-03-02</u>	Div. B / 5.3.1.3.(3)	Delete the Sentence referencing the standard CAN/ULC-S705.2 "Thermal Insulation - Spray Applied Rigid Polyurethane Foam, Medium Density, Installer's Responsibilities - Specification", this standard is referenced in Table 5.10.1.1.		mNBC
<u>B-05-04-01</u>	Div. B / 5.4.1.1.(1)(e)	Add new requirement to minimize the ingress of airborne radon from the ground with an aim to controlling the indoor radon concentration.	Radon Mitigation	Ontario
<u>B-05-04-02</u>	Div. B / 5.4.1.2.	Reference ASTM E2178 "Standard Test Method for Air Permeance of Building Materials" for testing air barrier materials.		mNBC
<u>B-05-06-01</u>	Div. B / 5.6.1.2.(1) Div. B / 5.6.1.2.(2)	Delete Sentences 5.6.1.2.(1) and (2) referencing standards related to the installation of protective materials which are already referenced in Table 5.10.1.1.		mNBC
<u>B-05-06-02</u>	Div. B / 5.6.2.1.	Amend appendix note to provide guidance on issues related to loadings on environmental separators such as air barriers and fenestrations.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-05-07-01</u>	Div. B / 5.7. Div. B / 5.8.	Combine Section 5.7., “Surface Water”, and Section 5.8., “Moisture in the Ground”, into a new Section 5.7., “Surface and Ground Water” and provide a description of the differences between waterproofing and dampproofing and address the need for attention to surface preparation.		mNBC
<u>B-05-09-01</u>	Div. B / 5.9.	Introduce a new sound transmission metric in order to consider flanking sound transmission contributions in addition to the direct sound transmission currently addressed.	Sound Transmission	mNBC
<u>B-05-10-01</u>	Div. B / 5.10.1.1.	Amend multiple referenced standards to address withdrawn and outdated standards and new standards.		mNBC
<u>B-05-10-02</u>	Div. B / 5.10.2.3.(1)	Address the importance of installation details and field testing of fenestration products to meet the level of performance required.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-05-10-03</u>	Div. B / 5.10.3.	<p>Establish minimum performance requirements as well as laboratory and in-situ standard test procedures for curtain wall, window wall, storefront and glazed architectural structures (referred as other fenestration assemblies).</p> <p>It will also provide guidance on how to properly identify these products and their applications by clarifying the recognized industry use of terms.</p>		mNBC
<u>B-05-10-04</u>	Div. B / 5.10.	Add a new appendix note to provide guidance on exterior insulation and finish system design and construction.		mNBC
<u>B-06-02-01</u>	Div. B / 6.2.1.1.(1)	Add reference to ANSI/AARST RMS-LB "Radon Mitigation Standards for Schools and Large Buildings".	Radon Mitigation	Ontario
<u>B-06-02-02</u>	Div. B / 6.2.1.4.(3)(a) Div. B / 6.2.2.1. Div. B / Table 6.2.4.2.	Revise Sentence 6.2.1.4.(3).(a) to replace "single dwelling unit" with <i>house</i> .	Secondary Suites	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-06-02-03</u>	Div. B / 6.2.1.6.	Facilitate the use of an energy recovery ventilator where a heat recovery ventilator is required or used.		Ontario
<u>B-06-02-04</u>	Div. B / 6.2.1.6.(3)	Require all non-forced air heating systems to have a heat recovery ventilator.		Ontario
<u>B-06-02-05</u>	Div. B / 6.2.1.8.(4)	Clarify Code requirements for indirect drainage piping.		Ontario
<u>B-06-02-06</u>	Div. B / 6.2.2.2.(3)	Add a new Sentence 6.2.2.2.(3) to require a mechanical ventilation system to introduce air to and circulate air throughout the dwelling unit.		Ontario
<u>B-06-02-07</u>	Div. B / 6.2.2.3.(1)	Add an appendix note to clarify that the ventilation of car dealership showrooms does not apply to "storage garages".		mNBC
<u>B-06-02-08</u>	Div. B / 6.2.2.4.(1) Div. B / 6.2.2.4.(3)	Clarify the meaning of "air contaminants".		mNBC
<u>B-06-02-09</u>	Div. B / 6.2.2.4.(5)	Require exhaust air system to be connected to smoke detector.	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-06-02-10</u>	Div. B / 6.2.2.6.	Clarify that the fire-resistance rating of factory-built and field-applied grease duct enclosures be determined in conformance with the CAN/ULC-S144, "Standard method of Fire-Resistance Test-Grease Duct Assemblies."	Fire Safety	mNBC
<u>B-06-02-11</u>	Div. B / 6.2.3.1. Div. B / 6.2.4.1. Div. B / 6.2.4.7.	Add new provision to allow not more than 2 dwelling units to share a forced air heating system.	Secondary Suites	Ontario
<u>B-06-02-12</u>	Div. B / 6.2.3.2.	Add a new Sentence 6.2.3.2.(1) to address the installation of drain pans serving heating, ventilation and air conditioning equipment.		mNBC
<u>B-06-02-13</u>	Div. B / 6.2.3.4. Div. B / 6.2.9.2.	Add a reference to TIAC "Mechanical Insulation Best Practices Guide" in the related appendix note to provide an example document of best practices when dealing with thermal insulation.		mNBC
<u>B-06-02-14</u>	Div. B / 6.2.3.4.	Introduce the use of foamed plastic insulation to insulate heating ducts in Part 9 buildings.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-06-02-15</u>	Div. B / 6.2.3.8.(8)	Add an appendix note to clarify the intent of Sentence 6.2.3.8.(8) of the Code related to the installation and access of dryer exhaust ducts to facilitate maintenance and cleaning.		mNBC
<u>B-06-02-16</u>	Div. B / 6.2.3.12.(2)	Add a new Sentence 6.2.3.12.(6) to address the minimum distance separation between air intake and exhaust openings.		mNBC
<u>B-06-02-17</u>	Div. B / 6.2.3.14.(3)	Clarify requirements to minimize the probability of poor indoor air quality caused by the legionella being entrained by the ventilation system related to evaporative air coolers, misters, air washers, atomizers and humidifiers.		mNBC
<u>B-06-02-18</u>	Div. B / 6.2.3.15.	Add three new Sentences (4) to (6) to address additional requirements related to the cooling towers, evaporative coolers and evaporative condensers.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-06-02-19</u>	Div. B / 6.2.9.2.(6)	Require exposed piping that may be subject to human contact to be insulated so that temperature of exposed surface does not exceed 40° C.		Ontario
<u>B-06-02-20</u>	Div. B / 6.2.12.	Expand requirements to install carbon monoxide alarms to spaces outside of residential suites.	Carbon Monoxide	Ontario
<u>B-06-02-21</u>	Div. B / 6.2.12.1.	Require all new buildings and additions and renovations to existing buildings to have carbon monoxide detectors regardless of occupancy i.e. storage garages and any buildings containing a fuel-burning appliance.	Carbon Monoxide	Ontario
<u>B-06-02-22</u>	Div. B / 6.2.12.2.(2)	Add a new Sentence to require a carbon monoxide alarm in common areas of a structure that contain no residential occupancy.	Carbon Monoxide	Ontario
<u>B-07-01-01</u>	Div. B / 7.1.4.2.(3)	Require Floor Drains to be installed in public washrooms.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-01-02</u>	Div. B / 7.1.4.2.(4)	Require a floor drain in a bathroom where a bath fixture without an overflow drain is installed.		Ontario
<u>B-07-01-03</u>	Div. B / 7.1.5.1.(1)	Connection of sanitary drainage systems to private sewer.		Ontario
<u>B-07-01-04</u>	Div. B / 7.1.5.2.(1)	Connection of storm drainage systems to private sewer.		Ontario
<u>B-07-02-01</u>	Div. B / 7.2.2.6.(1)	Clarify the intent of Sentence 7.2.2.6.(1).		Ontario
<u>B-07-02-02</u>	Div. B / 7.2.3.2.(4)	Add a new Sentence 7.2.3.2.(4) to clarify the selection and installation of grease interceptors.		Ontario
<u>B-07-02-03</u>	Div. B / 7.2.4.3.(1)	Prohibit the use of 90° elbows of 4 in. size or less to join two soil or waste pipes.		Ontario
<u>CC-B-07-02-01</u>	Div. B / 7.2.4.3.(3)	The proposed change would revise the Building Code's standard terminology to address wastewater heat recovery systems.	Climate Change	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-02-04</u>	Div. B / 7.2.5.1.	Remove references to CGSB standards related to asbestos pipe and fittings that have been withdrawn.		mNPC
<u>B-07-02-05</u>	Div. B / Table 7.2.5.9.	Remove the 90 degree C and 100 degree C values for CPVC piping since the product is not rated for above 82 degree C.		mNPC
<u>B-07-02-06</u>	Div. B / 7.2.5.10.(1)	Add a new reference document for non-perforated pipes, and Type 1 joints, for profile polyethylene (PE) storm sewer and drainage pipe and fittings.		mNPC
<u>B-07-02-07</u>	Div. B / 7.2.6.	Include ferrous pipes and fittings (stainless steel) in Part 7 as an additional and acceptable material that may be used in plumbing systems.		mNPC
<u>B-07-02-08</u>	Div. B / 7.2.6.1.	Add provisions for cast iron frames and covers for maintenance holes and catch basins that meet CSA B70.1 "Frames and Covers for Maintenance Holes and Catchbasins".		mNPC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>CC-B-07-02-02</u>	Div. B / 7.2.7.4.(4)	The proposed change would revise the Building Code's standard terminology to address wastewater heat recovery systems.	Climate Change	Ontario
<u>B-07-02-09</u>	Div. B / 7.2.7.4.(5)	Add a new Sentence to restrict the use of copper pipe for urinals.		mNPC
<u>B-07-02-10</u>	Div. B / 7.2.8.1.	Add an ASTM standard to the list of standards in 7.2.8.1. permitted for use as corrosion resistant pipes and fittings.		Ontario
<u>B-07-02-11</u>	Div. B / 7.2.10.2.	Permit alternative methods of mounting and attaching water closets to be consistent with modern fixtures.		mNPC
<u>B-07-02-12</u>	Div. B / 7.2.10.6.	Add a new Sentence 7.6.4.1.(3) to require lavatories in a public access washroom to be equipped with a device capable of automatically shutting off the flow of water when the lavatory is not in use and harmonize with the NPC requirement.		mNPC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-02-13</u>	Div. B / 7.2.10.7.	Delete Sentence referencing NSF/ANSI 61 certification required for domestic hot water tank linings. The standard is not applicable to domestic tanks.		Ontario
<u>B-07-02-14</u>	Div. B / 7.2.10.17.(2)	Add a new Sentence 7.2.10.17.(2) to clarify the connection requirement for a drinking water treatment system.		Ontario
<u>B-07-02-15</u>	Div. B / 7.2.11.20.	Revise the certification or conformance standards for Water Service Pipes and Fire Service Mains.		Ontario
<u>B-07-03-01</u>	Div. B / 7.3.2.8.	Include stainless steel welded joints in Part 7 as an additional and acceptable material which could be used in plumbing systems.		Ontario
<u>B-07-03-02</u>	Div. B / 7.3.3.8.	Permit alternative methods of mounting and attaching modern water closets.		mNPC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-03-03</u>	Div. B / 7.3.3.12.	Revise existing Article 7.3.3.12. to clarify compression fittings are not permitted to be used underground under a building.		Ontario
<u>B-07-03-04</u>	Div. B / 7.3.4.3.	Include requirements for insulation of support when using stainless steel pipe or tube.		mNPC
<u>B-07-03-05</u>	Div. B / 7.3.4.5.	Specify the maximum horizontal spacing of stainless steel supports.		mNPC
<u>B-07-03-06</u>	Div. B / 7.3.5.	Add a new Article to address the welding of stainless steel joints. (TG-SS SR #2).		mNPC
<u>B-07-03-07</u>	Div. B / 7.3.5.4.(1)	Add a reference to the TIAC Best Practices Guide in Appendix A to provide an example document of best practices when dealing with thermal insulation.		mNPC
<u>B-07-03-08</u>	Div. B / 7.3.6.1.(5)	Amend requirement for a ball test only when requested to reflect industry practice.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-04-01</u>	Div. B / 7.4.2.3.(2)	Allow indirect connections for floor drains in multi-level storage garages.		Ontario
<u>B-07-04-02</u>	Div. B / 7.4.4.3.(8)	Revise existing Sentence 7.4.4.3.(8) to permit an engineered grease interceptor with proprietary flow rates specially designed by the manufacturer.		Ontario
<u>B-07-04-03</u>	Div. B / 7.4.4.3.(9)	Clarify the permission to install either an internal or external flow control device as long as it is an integral part of the interceptor it serves.		Ontario
<u>B-07-04-04</u>	Div. B / 7.4.4.3.(11) Div. B / 7.4.4.3.(12)	Add new Sentences 7.4.4.3.(11) and (12) to address the requirements of drainage discharge from a commercial dishwasher.		Ontario
<u>B-07-04-05</u>	Div. B / 7.4.5.5.(1)	Add an appendix note where fixture faucet is used to maintain trap seal to require that the primer tube be looped above the fixture faucet.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>CC-B-07-04-01</u>	Div. B / 7.4.6.4.(1) Div. B / 7.4.6.4.(2) Div. B / 7.4.6.4.(3) Div. B / 7.4.6.4.(4) Div. B / 7.4.6.4.(5) Div. B / 7.4.6.4.(6)	<p>The proposed change would amend Article 7.4.6.4. and clarify the application of all referenced Sentences to support uniform enforcement by different municipalities and other principal authorities.</p> <p>These changes would require backwater valves to protect all building fixtures located below the level of the adjoining street or the upstream sanitary manhole cover in the case of residential buildings.</p> <p>The appendix note would be amended and clarified to indicate that backwater valves are required for fixtures located below the adjoining street or upstream manhole cover as above.</p>	Climate Change	Ontario
<u>B-07-04-06</u>	Div. B / 7.4.7.1.(1)	The proposed change clarifies the cleanout requirements for fixture drains.		mNPC
<u>B-07-04-07</u>	Div. B / 7.4.7.1.(10)	Permit a fully removable trap to be installed and amend language to be consistent with the existing appendix note.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-04-08</u>	Div. B / 7.4.7.1.(11)	The proposed change clarifies the cleanout requirements for fixture drains.		mNPC
<u>B-07-04-09</u>	Div. B / 7.4.7.1.(11)	Add a new cleanout requirement on a soil or waste stack that extends through five storeys or more and require the soil or waste stack serving a residential occupancy to be located adjacent to and accessible from the public corridor or a common area.		Ontario
<u>B-07-04-10</u>	Div. B / 7.4.9.3.(3)	Use a standard terminology to address the wastewater heat recovery system.		Ontario
<u>B-07-04-11</u>	Div. B / 7.4.9.3.	Clarify the requirement for a 2" vertical standpipe for clothes washers.		Ontario
<u>B-07-04-12</u>	Div. B / Table 7.4.9.3.	Replace all references to the term "trap" with "fixture outlet pipe".		Ontario
<u>B-07-04-13</u>	Div. B / Table 7.4.9.3.	Add notes to Table 7.4.9.3. to clarify that emergency floor drains have no hydraulic load for sizing purposes.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-05-01</u>	Div. B / 7.5.2.1.	Clarify that the wet vented portion is not to be reduced in size except for the portion that is upstream of floor drains in accordance with Clauses 7.5.1.1.(3)(a) and (c).		Ontario
<u>B-07-05-02</u>	Div. B / 7.5.3.1.(7)	Clarify that the minimum 2 inches of an additional circuit vent is only needed when the circuit vented branch is serving water closets.		Ontario
<u>B-07-05-03</u>	Div. B / 7.5.3.1.(11)	Revise the wording for hydraulic load on a circuit vent.		Ontario
<u>B-07-05-04</u>	Div. B / 7.5.5.5.(2) Div. B / 7.6.1.4.(4)	Revise Sentence 7.5.5.5.(2) to replace "single family dwelling" with <i>house</i> .	Secondary Suites	Ontario
<u>B-07-05-05</u>	Div. B / 7.5.5.5.(3)	Add a new Sentence for future vent installation where a gravity drain to sanitary drain is not possible		Ontario
<u>B-07-05-06</u>	Div. B / 7.5.9.1.(1)	Permit air admittance valves to be used with dual vents.		mNPC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-06-01</u>	Div. B / 7.6.1.5.(1)	Add requirement that water supply to each plumbing fixture be individually valved.		Ontario
<u>B-07-06-02</u>	Div. B / 7.6.2.2.(4)	Add a new Sentence (4) to require that trap seal cross connections are protected against backflow by a backflow preventer conforming to CAN/CSA B64.10.		Ontario
<u>B-07-06-03</u>	Div. B / 7.6.2.3.(4)	Clarify that CSA B64.10 addresses selection and installation of backflow protection and CSA B64.10.1. addresses maintenance and field testing.		Ontario
<u>B-07-06-04</u>	Div. B / 7.6.2.10.	Include permission to use spill-resistant pressure vacuum breakers.		mNPC
<u>B-07-06-05</u>	Div. B / 7.6.3.1.(1)	Add an appendix note to clarify the meaning of peak demand flow.		Ontario
<u>B-07-06-06</u>	Div. B / 7.6.3.3.(1)	Revise the upper limit of static pressure in water distribution system to 700 kPa.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>CC-B-07-06-01</u>	Div. B / 7.6.3.4.(5) Div. B / 7.6.3.4. (6)	The proposed change would revise Sentence 7.6.3.4.(5) and add a new Sentence (6) to permit a building occupied by one dwelling unit to be served by a minimum ¾ inch water supply piping located in the basement or lower level by extending it to the base of every hot and cold water riser that serves a maximum of one bathroom group and to the last water supply branch serving any basement bathroom group, fixture or hose bibb.	Climate Change	Ontario
<u>CC-B-07-06-02</u>	Div. B / 7.6.3.4.(7)	The proposed change would add a new Sentence 7.6.3.4.(7) to permit 2 or more parallel potable water coils on the potable water side of the drain water heat recovery (DWHR) units.	Climate Change	Ontario
<u>B-07-06-07</u>	Div. B / Table 7.6.3.4.	Permit higher water velocity to reflect materials currently available and used by industry and to harmonize with the NPC 2.6.3.4.		Ontario
<u>B-07-06-08</u>	Div. B / 7.6.5.2.(2)	Modify the wording of Sentence 7.6.5.2.(2) to ensure the correct device is being used to protect from scalding and thermal shock.		mNPC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-07-06-09</u>	Div. B / 7.6.5.3.(1)	Add day nurseries to the list of occupancies requiring temperature controls.		Ontario
<u>R-B-07-06-01</u>	Div. B / 7.6.5.3.(1)	This proposed change to Sentence 7.6.5.3.(1) requires that temperature controls on water supply fixtures are accessible to supervisory staff only in a retirement home.	Retirement Homes	Ontario
<u>CC-B-07-08-01</u>	Div. B / 7.8	The proposed change would relocate the existing SB-12 Drain Water Heat Recovery (DWHR) requirement to a new Section 7.8 of the Building Code and require drain water heat recovery (DWHR) units to be installed in dwelling units that are within the scope of Part 9 to receive drain water from all showers or at least two showers where there are two or more showers.	Climate Change	Ontario
<u>B-08-02-01</u>	Div. B / 8.2.1.4.(3)	The proposed change removes the reference to Article 8.2.1.5. in Sentence 8.2.1.4.(3) for clarification.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-08-02-02</u>	Div. B / 8.2.1.6.(2)	The proposed change amends Sentence 8.2.1.6.(2) and Table 8.2.1.6.B. to include clearances for leaching chambers.		Ontario
<u>B-08-04-01</u>	Div. B / 8.4.1.1.(2)	The proposed change adds a new Sentence to permit the construction of a Class 2 sewage system in another configuration in addition to the pit type.		Ontario
<u>B-08-04-02</u>	Div. B / 8.4.2.1.	The proposed change amends Sentences 8.4.2.1.(2) to (7) to reflect that a Class 2 sewage system may not necessarily be constructed as a pit.		Ontario
<u>B-08-04-03</u>	Div. B / 8.4.2.3.	The proposed change allows the bottom area of a Class 2 sewage system to be considered in the calculation of the sizing of the system.		Ontario
<u>B-08-06-01</u>	Div. B / 8.6.1.3.	The proposed change requires dosing of the effluent for chamber systems when the length exceeds 150 m and to require an alarm installed in the pump chamber to avoid a malfunction from going unnoticed.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-08-07-01</u>	Div. B / 8.7.2.1.(2)	The proposed change substitutes the term “percolation time” for “hydraulic conductivity” for clarification purposes.		Ontario
<u>B-08-07-02</u>	Div. B / 8.7.2.3.	The proposed change adds a new Article to address leaching chambers.		Ontario
<u>B-08-07-03</u>	Div. B / 8.7.3.2.	The proposed change adds a new Article to address the length of leaching chambers.		Ontario
<u>B-08-07-04</u>	Div. B / 8.7.3.2. Div. B / 8.7.3.3.	The proposed change amends the Article to renumber 8.7.3.2. and 8.7.3.3. to 8.7.3.3 and 8.7.3.4. respectively and amends Clause 8.7.3.3.(1)(d) to include leaching chambers.		Ontario
<u>B-08-07-05</u>	Div. B / 8.7.4.2.	The proposed change amends Sentences 8.7.4.2.(1) by removing the term “leaching bed fill” from specific places in the Sentence. This change would help ensure that there is existing soil at the site where the leaching bed is to be constructed.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-08-07-06</u>	Div. B / 8.7.5.3.	The proposed change amends Sentence 8.7.5.3.(2) to include leaching chambers and amends the reference in Sentence 7 to reflect the new numbering of the Article 8.7.3.3.		Ontario
<u>B-08-07-07</u>	Div. B / 8.7.7.1.	The proposed change amends Sentences 8.7.7.1.(3), (5), and (6) to reflect the inclusion of the leaching chambers when used as part of a Type A Dispersal Bed, and adds Sentences (6.1), and (10) to Article 8.7.7.1. for greater consistency regarding extension of the sand layer.		Ontario
<u>B-08-08-01</u>	Div. B / 8.8.1.2.	The proposed change amends Clause 8.8.1.2.(1)(c) to restrict the expansion of dwellings served by holding tanks.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-08-09-01</u>	Div. B / 8.9.2.3.	<p>The proposed change adds a new Sentence to require the keeping of maintenance records of Class 4 sewage systems and making them available for the chief building official upon request.</p> <p>The change also will require maintenance agreements to include provisions regarding effluent sampling.</p>		Ontario
<u>B-08-09-02</u>	Div. B / 8.9.2.4.(1)	The proposed change requires the maintenance provider to be responsible for the sampling of treatment units.		Ontario
<u>B-08-09-03</u>	Div. B / 8.9.3.4.	The proposed change requires regular pumping out of septic tanks and keeping of the septic tanks and treatment units' maintenance records.		Ontario
<u>B-09-01-01</u>	Div. B / 9.1.1.5.	Review application of requirement to not permit construction of a building under a 120v overhead cable.		Ontario
<u>B-09-01-02</u>	Div. B / 9.1.1.7.(1)	Add clause to require radon mitigation in geographic areas where radon is above 200 Bq/m3.	Radon Mitigation	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-01-03</u>	Div. B / 9.1.1.9.(1)	Remove the words "intended for residential occupancy" in 9.1.1.9.(1) with respect to manufactured buildings which will permit all buildings to be built to the CSA A277 "Procedure for Certification of Prefabricated Buildings, Modules and Panels".		Ontario
<u>B-09-03-01</u>	Div. B / 9.3.1.	Maintain concrete strength requirements in Part 9 as stated in CSA A23.1-09 "Concrete Materials and Methods of Concrete Construction".		mNBC
<u>B-09-03-02</u>	Div. B / 9.3.1.1. to Div. B / 9.35.1.1. (Various)	Replace the term "single dwelling unit" with the new proposed defined term <i>house</i> with respect to two unit houses.	Secondary Suites	Ontario
<u>B-09-05-01</u>	Div. B / Table 9.5.3.1.	Revise Table 9.5.3.1. to increase minimum ceiling heights in basement spaces to be consistent with other height requirements. Remove above grade requirement for bathroom, water closet room or laundry area.	Secondary Suites	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-06-01</u>	Div. B / 9.6.1.3.(1)	Delete the reference to an outdated CGSB standard for the structural design of glass and replace it with a reference to Part 4.		mNBC
<u>B-09-07-01</u>	Div. B / 9.7.4.2.(1)	Clarify performance requirements for doors in appendix note A-9.7.4.2.(1) under 9.7.4.2.(1).		mNBC
<u>B-09-08-01</u>	Div. B / 9.8.	Harmonize stair, landing, handrail and guard requirements with the mNBC.	Stairs, Guards & Handrails	mNBC
<u>B-09-08-02</u>	Div. B / 9.8.3.2.	Revise Sentence 9.8.3.2.(1) to permit a stair with fewer than three risers where there is no hazard presented.	Stairs, Guards & Handrails	Ontario
<u>B-09-08-03</u>	Div. B / 9.8.7.3.(2)	The proposed change deletes requirement for 300 mm horizontal handrail extension at the bottom of stairs.	Stairs, Guards & Handrails	Ontario
<u>B-09-09-01</u>	Div. B / 9.9.3.1.(1)	Harmonize dimensions of means of egress with mNBC.		Ontario
<u>B-09-09-02</u>	Div. B / 9.9.4.5.	Address the protection of exit facilities exposed to an adjoining roof.	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-09-03</u>	Div. B / 9.9.6.6.(3) Div. B / 9.9.6.6.(4)	Propose change to prohibit a door opening onto an adjacent surface of 600 mm below without any means of protection if a stair riser is not provided. Address height of threshold at exterior door to avoid a tripping hazard.		Ontario
<u>B-09-09-04</u>	Div. B / 9.9.6.7.(1)	Add permission to install electromagnetic locks on access to exit doors in Part 9.	Fire Safety	mNBC
<u>B-09-09-05</u>	Div. B / 9.9.6.7.	Revise the Door Latching, Locking and Opening Mechanisms requirements to include panic-type hardware similar to Part 3.	Fire Safety	Ontario
<u>B-09-09-06</u>	Div. B / 9.9.8.4.	Revise the Appendix note which clarifies the reasons for requirements in Subsection 9.9.8. regarding the remoteness of exits.		mNBC
<u>B-09-09-07</u>	Div. B / 9.9.10.1.	Require all floor levels, including unfinished basements, to have at least one window which can be used for egress where there is no door on that floor level. Increase size of basement egress window.	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-09-08</u>	Div. B / 9.9.11.2.(2)	Require new signage that warns people where parking and storage may obstruct the exterior exit doors.		mNBC
<u>B-09-09-09</u>	Div. B / 9.9.11.3.	Clarify the Code application regarding referenced standards for graphical symbols on exit signs.	Fire Safety	mNBC
<u>B-09-10-01</u>	Div. B / 9.10.1.3.	Add a referenced link for toe boards to Article 3.3.5.8.		Ontario
<u>B-09-10-02</u>	Div. B / 9.10.1.3.(6) Div. B / 9.10.9.5.	Maintain an exception which permits open stairways in unsprinklered buildings that was previously provided in Part 3.	Fire Safety	mNBC
<u>B-09-10-03</u>	Div. B / 9.10.9.14.	Revise provisions that deal with fire separations between dwelling units in houses.	Secondary Suites	Ontario
<u>R-B-09-10-01</u>	Div. B / 9.10.8.4.	Delete Article 9.10.8.4. to exclude all retirement homes from the provisions of Part 9.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-10-04</u>	Div. B / 9.10.10.3.(1)	Editorial changes to exceptions in 9.10.10.4 and 9.10.10.5. related to fire separation of service rooms.	Fire Safety	Ontario
<u>B-09-10-05</u>	Div. B / 9.10.11.2.	Revise to replace 'dwelling unit' with <i>house</i> .	Secondary Suites	Ontario
<u>B-09-10-06</u>	Div. B / 9.10.15.5.(1)	Delete reference to 9.10.8.	Fire Safety	Ontario
<u>B-09-10-07</u>	Div. B / 9.10.15.1.	Add reference to a <i>house</i> .	Secondary Suites	Ontario
<u>B-09-10-08</u>	Div. B / 9.10.15.2.	Revise Sentence (1)(b)(ii) by reducing the fire resistance rating for fire separations to 30 min.	Secondary Suites	Ontario
<u>B-09-10-09</u>	Div. B / 9.10.16.1.(4)	Revise the application of the requirement for unsprinklered concealed spaces in Part 9 buildings (harmonization with Article 3.1.11.5.).	Fire Safety	mNBC
<u>B-09-10-10</u>	Div. B / 9.10.17.10.	Introduce a new Sentence (2) for the protection of walk-in coolers or freezers consisting of factory-assembled panels containing foamed plastic insulation.	Fire Safety	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-10-11</u>	Div. B / 9.10.18.	Reference a new standard for testing the integration between two or more fire protection and life safety systems.	Fire Safety	mNBC
<u>B-09-10-12</u>	Div. B / 9.10.19.1.(1) Div. B / 9.10.19.8.	Permit an option to have a residential warning system, as well as the interconnection of heat detectors, carbon monoxide alarms, other life safety devices and remote monitoring capabilities and permit the supervision of the interconnected devices.	Fire Safety	mNBC
<u>B-09-10-13</u>	Div. B / 9.10.19.1.(3) Div. B / 9.10.19.3.(1)	Add appendix note for visual alarm installation to reduce triggers for photosensitive epilepsy	Accessibility	Ontario
<u>B-09-10-14</u>	Div. B / 9.10.19.3.	Add Sentence (2) to address the locations for smoke alarms for a shared egress facility and common areas of a house.	Secondary Suites	Ontario
<u>B-09-10-15</u>	Div. B / 9.10.19.5.	Add a new Sentence (2) to address the interconnection of smoke alarms for a shared egress facility and common areas of a house.	Secondary Suites	Ontario
<u>B-09-10-16</u>	Div. B / 9.10.20.1.(1)	Address sill height of openable windows.	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-10-17</u>	Div. B / 9.10.22.	Clarify protection and installation clearances for above range microwave/fan hood combinations.	Fire Safety	mNBC
<u>B-09-10-18</u>	Div. B / 9.10.22.2.(2)	Remove reference to asbestos millboard as an acceptable material for use above cooktops.	Fire Safety	mNBC
<u>B-09-11-01</u>	Div. B / 9.11.	Introduce a new sound transmission metric in order to consider flanking sound transmission contributions between, and alongside, dwelling units in addition to the direct sound transmission currently addressed.	Sound Transmission	mNBC
<u>B-09-13-01</u>	Div. B / 9.13.1.1.	Clarify the application of measures to control the ingress of water, moisture and soil gas.		mNBC
<u>B-09-13-02</u>	Div. B / 9.13.2.	Replace and/or delete outdated dampproofing standards, add performance criteria, and clarify the Subsection and make it consistent with the proposed standards.		mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-13-03</u>	Div. B / 9.13.3.	Replace and/or delete outdated waterproofing standards, adds performance criteria, and clarifies the Subsection and makes it consistent with the proposed standards.		mNBC
<u>B-09-13-04</u>	Div. B / 9.13.4.1.	Define the application of soil gas control and harmonize with the mNBC.	Radon Mitigation	Ontario
<u>B-09-13-05</u>	Div. B / 9.13.4.2.	Add provisions for soil gas control and harmonize with the mNBC.	Radon Mitigation	Ontario
<u>B-09-14-01</u>	Div. B / 9.14.3.1.	Delete the reference to a standard for asbestos cement drain pipe that has been withdrawn.		mNBC
<u>B-09-14-02</u>	Div. B / 9.14.5.1.(1)	Add a signpost to 7.4.5.3. to see options for disposal of foundation drainage water.		Ontario
<u>B-09-15-01</u>	Div. B / 9.15.3.4.	Clarify the meaning/use of supported joist spans for exterior walls and interior walls.	Structural Integrity	Ontario
<u>B-09-15-02</u>	Div. B / 9.15.5.1.(1)	Clarify that solid masonry units in the provisions listed are to be 100% solid with no unfilled cells/voids.	Structural Integrity	mNBC

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-15-03</u>	Div. B / 9.15.5.3.(3)	Clarify where a portion of the wall system must use solid masonry construction by ensuring the cells of the units are filled.	Structural Integrity	mNBC
<u>B-09-16-01</u>	Div. B / 9.16.4.5.	Increase the compressive strength of concrete floors-on-ground from 15 MPa to 20 MPa.		Ontario
<u>B-09-20-01</u>	Div. B / 9.20.2.1.(1)	Replace the existing four A82 series standards with the new reference standard CSA A82 "Fire Masonry Brick Made from Clay or Shale".		mNBC
<u>B-09-20-02</u>	Div. B / 9.20.5.2. Div. B / 9.20.6.4.(1)	Revise the thickness requirement of masonry veneer for each masonry unit is supported individually by the structural backing, masonry veneer.		Ontario
<u>B-09-20-03</u>	Div. B / 9.20.8.5.	Delete a type of construction that is not acceptable and can lead to ingress of water into the building envelope.		mNBC
<u>B-09-20-04</u>	Div. B / Table 9.20.9.5.	Update spacing of brick veneer tie spacing.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-21-01</u>	Div. B / 9.21.5.1.(1)	Delete the word "framing" from Sentence (1).		Ontario
<u>B-09-22-01</u>	Div. B / 9.22.9.3.	Delete the word "framing" from Sentence (1) and add the word "materials."		Ontario
<u>B-09-23-01</u>	Div. B / 9.23.5.	Add engineered components to prevent such elements from being notched or drilled unless allowed for in the design similar to roof trusses.	Structural Integrity	Ontario
<u>B-09-23-02</u>	Div. B / 9.23.16.1.	Add an Appendix note to differentiate between providing some support to cladding and the requirement to provide both lateral strength and structural support of the cladding.	Structural Integrity	Ontario
<u>B-09-23-03</u>	Div. B / 9.23.16.3.	Add an Appendix note to differentiate between providing some support to cladding and the requirement to provide both lateral strength and structural support of the cladding.	Structural Integrity	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-23-04</u>	Div. B / Table 9.23.17.2.A	Delete an outdated standard for gypsum board from a list of material standards and makes Part 5 and Part 9 references consistent.	Structural Integrity	mNBC
<u>B-09-25-01</u>	Div. B / 9.25.2.2.	Add a reference to ASTM C726, "Mineral Wool Roof Insulation Board," for applications for which there is currently no clear means of compliance and make Part 5 and Part 9 references consistent.		mNBC
<u>B-09-25-02</u>	Div. B / 9.25.2.3.(8)	Permit the use of alternative membrane materials to protect basement wall insulation.		Ontario
<u>B-09-25-03</u>	Div. B / 9.25.3.1.(1)(b)	Add a requirement for soil gas to be controlled by an air barrier.	Radon Mitigation	Ontario
<u>B-09-25-04</u>	Div. B / 9.25.3.3.	Add an appendix note to clarify use of spray foam as an air barrier.		Ontario
<u>B-09-25-05</u>	Div. B / 9.25.4.2.	Permit the installation of semi-permeable or variable permeance materials in basement wall assemblies.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-25-06</u>	Div. B / 9.25.5.	Reduce the trigger value on which the design and construction of wall assemblies is based - where they contain low permeance materials within the assembly.		mNBC
<u>B-09-26-01</u>	Div. B / 9.26.1.1. Div. B / 9.26.1.2.	Revise 9.26.1.1. to clarify the terms "roof" and "roofing", and add a new Article 9.26.1.2. to clarify the application of the requirements.		mNBC
<u>B-09-26-02</u>	Div. B / 9.26.2.1.	Remove references to withdrawn or obsolete CGSB standards and clarifies which standards apply to specific materials.		mNBC
<u>B-09-26-03</u>	Div. B / 9.26.2.	Add a new Article stating that materials listed in the new Table 9.26.2.1. be installed in accordance with manufacturer's instructions. This replaces the need for application standards.		mNBC
<u>B-09-26-04</u>	Div. B / 9.26.13.2.(1)	Correct language related to specified snow and live loads for roofs.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-27-01</u>	Div. B / 9.27.8.1.	Replace an outdated standard for hardwood and decorative plywood with a more up-to-date standard and makes Part 5 and Part 9 references consistent.		mNBC
<u>B-09-27-02</u>	Div. B / 9.27.1.1. Div. B / 9.27.13.	Clarify the requirements to address acceptable performance of Exterior Insulation Finish Systems in Part 9 by adding appendix notes.		mNBC
<u>B-09-29-01</u>	Div. B / 9.29.2.1.(1)	Clarify where waterproofing provisions are required for freestanding bathtubs.		Ontario
<u>B-09-32-01</u>	Div. B / 9.32.1.1. Div. B / 9.32.1.4.	Add a new Article for general provisions for laundry/dryer equipment venting in residential occupancies, and to be consistent with Part 6.	Fire Safety	mNBC
<u>B-09-32-02</u>	Div. B / 9.32.1.3.(1)	Clarify that the requirement for natural ventilation is applicable to all residential occupancies.		Ontario
<u>B-09-33-01</u>	Div. B / 9.33.2.2.	Add furnace size limits as limits are no longer addressed in CSA F280.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>B-09-33-02</u>	Div. B / 9.33.2.3.	Require that the performance of a combined space and water heating system be determined in accordance with CAN/CSA – P.9.		Ontario
<u>CC-B-09-34-01</u>	Div. B / 9.34.1.6.	The proposed change would require electric vehicle charging equipment for all houses where parking is provided and for all other Part 9 buildings where parking is provided in the building, except for multi-unit apartment buildings.	Climate Change	Ontario
<u>B-09-34-01</u>	Div. B / 9.34.2.7.(1)	Add a Sentence requiring a minimum average illumination level in egress facilities to be consistent with industry practice.		Ontario
<u>B-09-35-01</u>	Div. B / 9.35.3.3.	Address exemptions and permissions related to slabs and foundations of small detached garages.		mNBC
<u>B-09-36-01</u>	Div. B / 9.36.2.2.(1)	Delete the requirement related to cottages as it is found elsewhere in Code.		Ontario
<u>B-09-38-01</u>	Div. B / 9.38.3.2.	Remove spatial separation exemptions for cottages and park model trailers.	Fire Safety	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-09-40-01</u>	Div. B / 9.40.1.1.	Delete Clause 9.40.1.1.(1)(e) in order to align with the proposed change that excludes retirement homes from Part 9 of the Building Code.	Retirement Homes	Ontario
<u>R-B-10-01-01</u>	Div. B / 10.1.1.2.(1) Div. B / 10.3.2.2.(12)	Change to Sentences 10.1.1.2.(1) and 10.3.2.2.(12) are required as a result of the proposed defined term <i>retirement home</i> .	Retirement Homes	Ontario
<u>B-11-02-01</u>	Div. B / 11.2.1.1.A	Clarify application of Code where the building area and building height are constructed below grade.		Ontario
<u>R-B-11-02-01</u>	Div. B / Table 11.2.1.1.I	Revise Table 11.2.1.1.I provisions for retirement homes to align with provisions for other care occupancies where occupants require assistance in an emergency.	Retirement Homes	Ontario
<u>R-B-11-03-01</u>	Div. B / 11.3.3.1.(2)	Revise Sentence 11.3.3.1.(2) based on new defined term <i>retirement home</i> .	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-11-03-02</u>	Div. B / 11.3.3.2.(6)	Revise Sentence 11.3.3.2.(6) based on new defined term <i>retirement home</i> .	Retirement Homes	Ontario
<u>R-B-11-04-01</u>	Div. B / 11.4.2.3.(1)	Revise Sentence 11.4.2.3.(1) based on new defined term <i>retirement home</i> .	Retirement Homes	Ontario
<u>B-11-04-01</u>	Div. B / 11.4.2.3.(1)(d)	Clarify that changing a building from a <i>farm building</i> designation is considered a reduction to the performance level of the building.		Ontario
<u>B-11-04-02</u>	Div. B / 11.4.2.3.(4)	Clarify that Compliance Alternative C152 may be used for houses.		Ontario
<u>B-11-04-03</u>	Div. B / 11.4.3.4.(4)	Clarify that Compliance Alternative C152 may be used for houses.		Ontario
<u>R-B-11-04-02</u>	Div. B / 11.4.3.4.(7)	Revise Sentence 11.4.3.4.(7) based on newly defined term <i>retirement home</i> .	Retirement Homes	Ontario
<u>R-B-11-05-01</u>	Div. B / 11.5.1.1.(1)	Revise Article 11.5.1.1. and Table 11.5.1.1.B. to extend current levels of safety to apply to retirement homes subject to renovations.	Retirement Homes	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>R-B-11-05-02</u>	Div. B / 11.5.1.1.(1)	Revise Table 11.5.1.1.C. to extend current levels of safety to apply to retirement homes subject to renovations.	Retirement Homes	Ontario
<u>B-12-02-01</u>	Div. B / 12.2.1.2.	To harmonize requirements of Part 12 with the requirements of the July 7, 2016 dated Supplementary Standard SB-12.		Ontario
<u>B-12-02-02</u>	Div. B / 12.2.1.2.(4)	To delete the exemption of manufactured homes from the conformance to energy efficiency requirements. This will clarify that manufactured homes must conform to the energy efficiency requirements in existing Sentence 12.2.1.2.(4)		Ontario
<u>B-12-03-01</u>	Div. B / Part 12	Change various references in Part 12 from single dwelling unit to the new proposed definition of house.	Secondary Suites	Ontario
<u>B-12-03-02</u>	Div. B / 12.3.1.6.(2)	Require a dwelling to be provided with a 120 V outlet in addition to a natural gas or propane line.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>C-01-02-01</u>	Div. C / 1.2.1.2.(1) Div. C / 1.2.2.1.(4) Div. A / 1.4.1.2.(1)	Add a new Sentence that requires that where foundations of an existing building are underpinned, the foundations shall be designed by a professional engineer.	Structural Integrity	Ontario
<u>R-C-01-02-01</u>	Div. C / 1.2.2.1. Div. C / Table 1.2.2.1.	General Review: Revise Division C Table 1.2.2.1. to require Architect and Engineer general review for all licensed retirement homes regardless of size.	Retirement Homes	Ontario
<u>C-01-02-02</u>	Div. C / 1.2.2.1.	Include a provision that requires that the construction and installation of a demountable event structure be reviewed by a professional engineer.	Demountable Event Structures (Temporary Stages)	Ontario
<u>R-C-01-03-01</u>	Div. C / 1.3.1.3.	Set timeframes for permit reviews.	Retirement Homes	Ontario
<u>C-01-03-01</u>	Div. C / 1.3.1.1.(1)(a)	Require a permit for the demolition of houses on farms.		Ontario
<u>C-01-03-02</u>	Div. C / 1.3.1.3.	Include a provision that exempts certain Demountable Event Structures (Temporary Stages) from the requirement to obtain a building permit.	Demountable Event Structures (Temporary Stages)	Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>C-01-03-03</u>	Div. C / 1.3.1.3.	Includes a provision that specifies the period within which a permit must be granted or refused for designated structures.	Demountable Event Structures (Temporary Stages)	Ontario
<u>C-01-03-04</u>	Div. C / Table 1.3.1.3.	Address the period of time to issue a permit for secondary suites.	Secondary Suites	Ontario
<u>R-C-01-03-02</u>	Div. C / 1.3.1.4.	Revise Table 1.3.1.4. to clarify change of use requirements for retirement homes.	Retirement Homes	Ontario
<u>R-C-01-03-03</u>	Div. C / 1.3.3.2.	Clarify that occupancy provisions applicable to small residential buildings do not apply to retirement homes and that life safety systems need to be functional in the areas to be occupied in all retirement homes including the smallest ones.	Retirement Homes	Ontario
<u>C-01-03-05</u>	Div. C / 1.3.5.1.	Add a requirement related to readiness to place concrete that Part 9 foundation walls be reinforced with rebar.		Ontario

Code Change Number	Code Reference	Proposed Code Change	Topic	Source
<u>C-03-01-01</u>	Div. C / 3.1.5.1.(2) Div. C / 3.1.5.1.(4) Div. C / 3.2.4.3.(2) Div. C / 3.2.5.3.(2) Div. C / 3.3.3.3.(2) Div. C / 3.4.3.3.(2)	Revise the requirement for when a registration renewal must be submitted ahead of the expiry date from 60 days to 30 days.		Ontario
<u>C-03-02-01</u>	Div. C / 3.2.4.1.(3)(a) Div. C / 3.2.4.1.(3)(b)	Clarify that designers are also exempt from firm registration if they are an officer director, partner, proprietor or employee of a firm that is a TARION builder. The requirements for “other designer” registration under 3.2.5 are not affected.		Ontario
<u>C-03-02-02</u>	Div. C / 3.2.4.1.(4) Div. C / Table 3.5.2.1.	The proposed changes are editorial changes affecting the new proposed definition of <i>house</i> .		Ontario
<u>C-03-02-03</u>	Div. C / 3.2.5.1.	Require that a person who designs a new house be a registered BCIN designer under the Building Code (or an architect or professional engineer).		Ontario

Ministry of Municipal Affairs

© Queen's Printer for Ontario, 2016

ISBN 978-1-4606-8659-1 (PDF)

ISBN 978-1-4606-8660-7 (HTML)

08/16